

(Use this form to file a local law with the Secretary of State.)

Text of law should be given as amended. Do not include matter being eliminated and do not use italics or underlining to indicate new matter.

County

City

Town of Hague

Village

Local Law No. 1 of the year 2005.

A local law Amending the Sewer Use Local Law #3 of 2002.

(insert title)

Be it enacted by the Town Board of the

County

City

Town of Hague as follows:

Village

TOWN OF HAGUE

AMENDMENTS TO SEWER USE LOCAL LAW

General Table Of Contents

Article	Title
1	Short Title and Purpose
2	Definitions
3	Use of Public Sewers Required
4	New Sewers or Sewer Extensions
5	Building Laterals, Street Laterals, Connections, and Fees
6	Inflow
7	Trucked and Hauled Wastes

8	Discharge Restrictions
9	Discharge Permits and Pretreatment Requirements
10	Enforcement and Penalties
11	Charges
12	Public Disclosure of POTW Operation
13	Conflicts, Severability, Effective Date and Applicability
Appendix	Table of Parameters of Concern

Specific Table of Contents

Article 1 - Short Title and Purpose

- Section 101 - Short Title
- Section 102 - General Purpose
- Section 103 - Specific Purposes
- Section 104 – Continuance of Previous Sewer Use Law

Article 2 - Definitions

- Section 201 - Defined Terms
- Section 202 - Abbreviations
- Section 203 - Undefined Terms

Article 3 - Use of Public Sewers Required

- Section 301 - Waste Disposal Unlawful
- Section 302 - Connecting Private Sewage System to Storm Sewer Unlawful
- Section 303 - Discharge of Sewage into Well Prohibited
- Section 304 - Wastewater Discharge Unlawful
- Section 305 - Building Permit Allowed Only When Approved Wastewater Disposal Available
- Section 306 - Private Wastewater Disposal Unlawful
- Section 307 - Connection to Public Sewer Required
- Section 308 - Limitation on Use of Public Sewers
- Section 309 - Wastewater from Outside the POTW Service Area- Inter-municipal Agreements
- Section 310 - Moratorium
- Section 311 - Basis of Sewer Use Requirement

Article 4 - New Sewers or Sewer Extensions

- Section 401 - Proper Design
- Section 402A - New Sewers Subject to Approval, Fees, Inspection, Testing, and Reporting
- Section 402B - Plans, Specification, and Pipe Test Results Required

Section 403A - Sewer Pipe
Section 403B - Safety and Load Factors
Section 403C - Sewer Pipe installation
Section 403D - Cleanout Installation
Section 404 - Manholes and Manhole Installation
Section 405A - Infiltration/Exfiltration Testing
Section 405B - Test Section
Section 405C - Test Period
Section 405D - Pipe Lamping
Section 405E - Deflection Testing
Section 405F - Air Testing Alternative
Section 405G - Vacuum Testing Alternative
Section 406A - Force Mains
Section 406B - Force Main Testing
Section 407 - Final Acceptance and Warranty/Surety
Section 408 - Liability Insurance Coverage During Construction Period

Article 5 - Building Laterals, Street Laterals, Connections, and Fees

Section 501A - Permit Required for Sewer Connections
Section 501B - Inflow/Infiltration Prohibited
Section 502 - Sewer Lateral Permits
Section 503A - New Building Laterals
Section 503B - Laterals Serving Several Buildings
Section 503C - Laterals Serving Complexes
Section 503D - Dry Sewers
Section 504 - Using Existing Building Laterals
Section 505 - Lateral Pipe Materials
Section 506A - Street Lateral to Public Sewer Connection
Section 506B - Future Connection Locations; As-Built Drawings
Section 506C - Special Manhole Requirements
Section 507 - Laterals At and Near Buildings
Section 508 - Sewage Lifting
Section 509 - Lateral Pipe Installation
Section 510A - Watertight Joints
Section 510B - Cast Iron Pipe Poured Joints
Section 510C - Cast Iron Push Joints
Section 510D - PVC Push Joints
Section 511A - Building Lateral/Street Lateral Connection
Section 511B - Cleanout Repair/Replacement
Section 511C - Street Lateral Replacement; Ownership
Section 512 - Testing
Section 513A - Connection Inspection
Section 513B - Trench Inspections
Section 514 - Public Safety Provisions Required; Restoration of Disturbed Areas
Section 515 - Interior Clean-Out

Section 516 - Costs Borne by Owner

Article 6 - Inflow

Section 601 - New Inflow Sources Prohibited

Section 602 - Existing Inflow Sources Disconnected

Section 603 - Existing Inflow Sources Disconnected When Property Sold

Section 604 - No Re-connection of Inflow Source Allowed

Section 605 - Charges for Inflow

Article 7 - Trucked or Hauled Waste

Section 701 - Licenses and Application

Section 702 - Concurrent Requirements

Section 703 - Dumping Location and Timing

Section 704 - Notification of Dumping

Article 8 - Discharge Restrictions

Section 801 - Pretreatment Standards

Section 802 - General Prohibitions

Section 803 - Concentration Based Limitations

Section 804 - Mass Discharge Based Limitations

Section 805 - Modification of Limitations

Section 806 - Access to User's Records

Section 807 - Dilution

Section 808 - Grease, Oil, and Sand Interceptors

Section 809 - Solid Waste Grinders

Section 810 - Rejection of Wastewater

Article 9 - Discharge Permits and Pretreatment Requirements

Section 901 - Wastewater Discharge Reports

Section 902 - Notification to Industrial Users

Section 903A - Wastewater Discharges

Section 903B - Wastewater Discharge Permits Required For Significant Industrial Users

Section 903C - Other Industrial Users

Section 903D - Discharge Permits to Storm Sewers Not Authorized

Section 904A - Application for Wastewater Discharge Permits

Section 904B - Permit Modifications

Section 904C - Permit Conditions

Section 904D - Permit Duration

Section 904E - Permit Reissuance

Section 904F - Permit Transfer

Section 904G - Permit Revocation

Section 904H - Public Notification

Section 905 - Reporting Requirements for Permittee
Section 906 - Flow Equalization
Section 907 - Monitoring Stations (Control Manholes)
Section 908 - Proper Design and Maintenance of Facilities and Monitoring Stations
Section 909 - Vandalism, Tampering with Measuring Devices
Section 910 - Sampling and Analysis
Section 911 - Accidental Discharges; SPCC Plan
Section 912 - Posting Notices
Section 913 - Sample Splitting
Section 914 - Public Access to Information Maintained by the Zoning Enforcement Officer
Section 915A - Access to Property and Records
Section 915B - Access to Easements
Section 915C - Liability of Property Owner
Section 916 - Special Agreements

Article 10 - Enforcement and Penalties

Section 1001 - Enforcement Response Plan

Administrative Remedies

Section 1002 - Notification of Violation
Section 1003 - Consent Orders
Section 1004 - Administrative or Compliance Orders
Section 1005 - Administrative Fines
Section 1006 - Cease and Desist Orders
Section 1007 - Termination of Permit
Section 1008 - Water Supply Severance
Section 1009 - Show Cause Hearing
Section 1010 - Failure of User to Petition the Town
Section 1011 - Notice
Section 1012 - Right to Choose Multiple Remedies

Judicial Remedies

Section 1113 - Civil Actions for Penalties
Section 1114 - Court Orders
Section 1115 - Criminal Penalties
Section 1116 - Injunctive Relief
Section 1117 - Summary Abatement

Miscellaneous

Section 1118 - Delinquent Payments
Section 1119 - Performance Bonds
Section 1120 - Liability Insurance
Section 1121 - Informant Rewards

Section 1122 - Public Notification
Section 1123 - Contractor Listings

Article 11 - Charges

Section 1101 - Normal Sewage Service Charges
Section 1102 - Surcharge for Abnormal Sewage
Section 1103 - Total Sewer Service Charge
Section 1104 - Segmenting the POTW
Section 1105 - Measurement of Flow
Section 1106 - Billing Period
Section 1107 - Pretreatment Program Costs
Section 1108 - Charges for Trucked or Hauled Waste
Section 1109 - Capital Recovery
Section 1110 - Collection of Charges
Section 1111 - Fiscal Year for System
Section 1112 - Impact Fees
Section 1113 - Use of Revenues
Section 1114 - Records and Accounts

Article 12 - Public Disclosure of POTW Operations

Section 1201 - POTW Operations Open to the Public
Section 1202 - Procedural Requirements Available
Section 1203 - Validity Through Public Inspection

Article 13 - Conflicts, Severability, Effective Date and Applicability

Section 1301 - Conflicts
Section 1302 - Severability
Section 1303 - Effective Date
Section 1304 - Applicability

Appendix - Parameters of Concern

Class A - Halogenated Hydrocarbons
Class B - Halogenated Organics (Other than Hydrocarbons)
Class C - Pesticides (Includes Herbicides, Algaecides, Biocides, Slimicides and Mildewcides)
Class D - Aromatic Hydrocarbons
Class E - Tars
Class F - Substituted Aromatics (Other than Hydrocarbons and Non-Halogenated)
Class G - Miscellaneous
Class M - Metals and their Compounds

Article 1

Short Title and Purpose

Section 101 - Short Title
Section 102 - General Purpose
Section 103 - Specific Purposes
Section 104 - Continuance of Previous Sewer Use Law

Section 101 - Short Title

For brevity and ease of communication, this Law may be cited as the Town of Hague Sewer Use Law.

Section 102 - General Purpose

The general purpose of this Law is the following:

To provide for efficient, economic, environmentally safe, and legal operation of the Town of Hague POTW and the design and operation of all sewage disposal systems within the Town of Hague

Section 103 - Specific Purposes

The specific purposes of this Law are the following: (1) To prevent the introduction of substances into the POTW that will:

1. interfere with the POTW in any way,
2. pass through the POTW to the state's waters and cause contravention of standards for those waters or cause violation of the POTW's SPDES permit,
3. increase the cost or otherwise hamper the disposal of POTW sludge and/or residuals,
4. endanger municipal employees,
5. cause air pollution, or groundwater pollution, directly or indirectly,
6. cause, directly or indirectly, any public nuisance condition.

(2) To prevent new sources of infiltration and inflow and, as much as possible, eliminate existing sources of infiltration and inflow.

(3) To assure that new sewers and connections are properly constructed.

(4) To provide for equitable distribution to all users of the POTW of all costs, associated with sewage transmission, treatment, and residuals disposal, and to provide for the collection of such costs.

(5) To promote the health safety and welfare of the community by ensuring that all private wastewater disposal systems are properly designed, located, constructed and operated.

Section 104 - Continuance of Previous Sewer Use Law

The Septic Regulations of the Town of Hague enacted June 20, 1987 shall remain in full force and effect as amended.

Article 2

Definitions

Section 202 – Defined Terms

Section 202 - Abbreviations

Section 203 - Undefined Terms

Section 201 - Defined Terms Unless otherwise stated in the section where the term is used

in this Law, the meaning of terms used in this Law shall be as stated below. When not inconsistent with the context, the present tense shall include the future, and words used in the plural shall include the singular and vice versa. Furthermore, a masculine pronoun shall include the feminine. Shall is mandatory; may is permissive.

Abnormal Sewage - Sewage whose concentration of one or more characteristics of normal sewage exceeds the maximum concentrations of the characteristics of normal sewage. See normal sewage.

Act or "THE ACT" - The Federal Water Pollution Control Act, also known as the Clean Water Act, as amended, 33 U.S.C. 1251, et seq., as may be amended.

Administrator - The Regional Administrator of the U. S. Environmental Protection Agency (USEPA), Region 2.

Ammonia - The result obtained, using an approved laboratory procedure, to determine the quantity of ammonia in a sample, expressed as milligrams of nitrogen per liter.

Applicant - That person who makes application for any permit. The applicant may be an owner, new or old, or his agent.

Approval Authority - The USEPA, or the New York State Department of Environmental Conservation (NYSDEC), in the event the NYSDEC is delegated approval authority responsibility by the USEPA.

Approved Laboratory Procedure - The procedures defined as 'Standard Methods' in this article, or other procedures approved by the Wastewater Treatment Plant Operator, for flow measurement or determination of the concentration of pollutants or their surrogates in waters, wastewaters, and/or sludges.

ASTM, denoting American Society for Testing and Materials - The latest edition of any ASTM specification, when stipulated in this Law.

Authorized Representative of the Industrial User - An authorized representative of the industrial user may be: a) A principal executive officer of at least the level of vice-president, if the industrial user is a corporation; (b) A general partner or proprietor, if the industrial user is a partnership or proprietorship, respectively;(c) A duly authorized representative of the individual designated above, if such representative is responsible for the overall operation of the facilities from which the indirect discharge originates.

BOD, denoting Biochemical Oxygen Demand - The result obtained when using an approved laboratory procedure to determine the quantity of oxygen utilized in the aerobic biochemical oxidation of organic matter or in a sample, expressed in milligrams per liter.

Builder - Any person who undertakes to construct a building or any part of a building, either under contract or for resale.

Building Drain - That part of the lowest horizontal piping of a building drainage system

which receives the discharge from soil, waste, and other drainage pipes inside the building walls, and conveys it to the building lateral, which begins five (5) feet outside the inner face of the building wall.

Chlorine Demand - The result obtained when using an approved laboratory procedure to determine the difference between the amount of chlorine added to a sample and the amount of chlorine remaining in the sample at the end of a specified contact time at room temperature, expressed in milligrams per liter.

COD, denoting Chemical Oxygen Demand - The result obtained when using an approved laboratory procedure to measure the oxygen requirement of that portion of matter, in a sample, that is susceptible to oxidation, by a specific chemical oxidant, expressed in milligrams per liter.

Color - The optical density at the visual wavelength of maximum absorption, relative to distilled water. One hundred percent (100%) transmittance is equivalent to zero (0.0) optical density.

Composite Sample - The sample resulting from the combination of individual samples of wastewater taken at selected intervals, for a specified time period. The individual samples may have equal volumes or the individual volumes may be proportioned to the flow at the time of sampling.

Connection - Attachment of one user to a sewer. (See Extension)

Connection Charge (Tap Fee) - The one time application fee to offset Town of Hague expenses to process an application for a connection of a building/street lateral to the public sewer. The fee also covers plan review, permit issuance, street repair cost, and inspection costs. The fee may be scaled to the amount of work involved, or to the size of the public sewer involved.

Control Authority - The term shall refer to "Approval Authority", or to the Wastewater Treatment Plant Operator when Town of Hague has an approved pretreatment program under the provisions of 40 CFR 403.11.

Control Manhole - A manhole accessible to the Control Authority in or upstream of the street lateral, such that samples collected from the manhole represent the discharge to the POTW.

Conventional Pollutant - A pollutant that the POTW treatment plant was designed to treat, defined in accordance with the Act.

Cooling Water - The water discharged from any system of condensation, air conditioning, refrigeration, or other sources. It shall contain no polluting substances which would produce COD or suspended solids in excess of five (5) milligrams per liter, or toxic substances, as limited elsewhere in this Law.

County - The county in which the Town of Hague is located.

Developer - Any person who subdivides land for the purpose of constructing, or causing to be constructed, buildings for which wastewater disposal facilities are required.

Direct Discharge - The discharge of treated or untreated wastewater directly to the Waters of the State of New York. (For reference, see Indirect Discharge.)

Domestic Wastes - see Sewage, Domestic.

Dry Sewers - The sanitary sewer installed in anticipation of future connection to a POTW but which is not used, in the meantime, for transport of storm or sanitary sewage.

End of Pipe - For the purpose of determining compliance with limitations prescribed by Article 9, end of pipe shall mean the control manhole, provided the samples collected from the control manhole are representative of the discharge to the POTW.

End of Pipe Concentration - The concentration of a substance in a sample of wastewater at end of pipe.

End of Process Concentration - see National Categorical Pretreatment Standard.

Easement - An acquired legal right for the specific use of land owned by others.

EPA, USEPA, or U.S. Environmental Protection Agency - The agency of the federal government charged with the administration and enforcement of federal environmental laws, rules, and regulations. Also may be used as a designation for the Administrator or other duly authorized official of this Agency.

Extension - Attachment of a sewer line, with more than one user, to an existing sewer line.

Facility - All buildings, other structures, grounds and contiguous property at any locations related to or connected with a user at the user's location.

Floatable Oil - Oil, grease, or fat in a physical state such that it will separate by gravity from wastewater by treatment in a wastewater treatment facility.

Flow Rate - The quantity of liquid or waste that flows in a certain period of time.

Garbage - The solid wastes from the preparation, cooking, and dispensing of food, from the handling, storage, and sale of produce, and from the packaging and canning of food.

Grab Sample - A single sample of wastewater representing the physical, chemical, and biological characteristics of the wastewater at one point and time.

ICS Form - The form used by the NYSDEC to survey industries to perform and update the Industrial Chemical Survey.

Indirect Discharge - The introduction of wastewater into a POTW for treatment and ultimate discharge of the treated effluent to the State's Waters. (For reference, see Direct Discharge).

Industrial - Meaning or pertaining to industry, manufacturing, commerce, trade, business, or institution, and is distinguished from domestic or residential.

Industrial Chemical Survey (ICS) - The survey of industries in New York State, initiated by the NYSDEC, to determine chemical usage and storage by those industries.

Industrial User - See User, Industrial.

Industrial Wastes - The liquid or liquid-carried solid, liquid and/or gaseous wastes from industrial manufacturing processes, trade, service, utility, or business, as distinct from sanitary sewage.

Infiltration - Water, other than wastewater, that enters a sewer system (excluding building drains) from the ground through such means as defective pipes, pipe joints, connections, or manholes. Infiltration does not include, and is distinguished from, inflow. Infiltration is inadvertent, that is, not purposely designed or built into the sewer or drain.

Inflow - Water, other than wastewater, that enters a sewer system (including building drains) from sources such as, but not limited to, roof leaders, cellar drains, area drains, drains from springs and swampy areas, manhole covers, cross connections between storm sewers and sanitary sewers, catch basins, cooling towers, storm waters, foundation drains, swimming pools, surface runoff, street wash waters, or drainage. Inflow does not include, and is distinguished from, infiltration. Inflow is purposely designed and/or built into the sewer or drain.

Interference - A discharge which, alone or in conjunction with discharges by other sources,

(a) inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and

(b) therefore is a cause of a violation of any requirement of the (C,V,T) POTW's SPDES permit (including an increase in the magnitude or duration of a violation) or of the prevention of sewage sludge use or disposal by the POTW in accordance with the following statutory provisions and regulations or permits issued there under (or more stringent State or local regulations):

i - Section 405 of the Clean Water Act,

ii - the Solid Waste Disposal Act (SWDA) (including Title II, more commonly referred to as the Resource Conservation and Recovery Act - RCRA), and including State regulations

contained in any State sludge management plan prepared pursuant to Subtitle D or the SWDA),

iii - Clean Air Act,

iv - Toxic Substance Control Act, and

v - Marine Protection Research and Sanctuaries Act.

Lateral, Building - The sewer extension from the building drain to the Street Lateral or other place of wastewater disposal.

Lateral, Street - The sewer extension from the public sewer to the property line.

National Categorical Pretreatment Standard, or Categorical Standard - Any regulation containing pollutant discharge limits promulgated by the EPA in accordance with Section 307 (B) and (C) of the Act (22 U.S.C. 1347), which applies to a specific category of industrial users. These standards apply at the end of the categorical process ("end of process").

National Pollutant Discharge Elimination System (NPDES) Permit - A permit issued pursuant to Section 402 of the Act (33 U.S.C. 1342).

National Prohibitive Discharge Standard, or Prohibitive Discharge Standard - Any regulation developed under the authority of Section 307 (B) of the Act, and 40 CFR, Section 403.5.

Natural Outlet - Any outlet, including storm sewers and combined sewer overflows, to State's Waters.

New Owner - That individual or entity who purchased property within the Service Area of the Town of Hague after the effective date of this law.

New Source - Any source, the construction of which is commenced after the publication of the proposed regulation prescribing a Section 307 (C) (33 U.S.C 1317) Categorical Pretreatment Standard which will be applicable to such source, if such standard is thereafter promulgated.

New User - A discharger to the POTW who commences discharge after the effective date of this Law.

Normal Sewage - see Sewage, Normal.

Nuisance - The use or lack of use of the POTW in such a manner so as to endanger life or health, give offense to the senses, or obstruct or otherwise interfere with the reasonable use or maintenance of the POTW.

Oil and Grease - The result obtained when using an approved laboratory procedure to determine the quantity of fats, wax, grease, and oil, in a sample, expressed in milligrams per

liter.

Old Owner - That individual or entity who owns or owned a property, within the Service Area of the POTW, purchased prior to the effective date of this Law, who or inherited the property at any time and intends to sell the property, or has sold the property to a new owner, also the agent of the old owner.

Other Wastes - Garbage (shredded or unshredded), refuse, wood, egg shells, coffee grounds, sawdust, shavings, bark, sand, lime, ashes, and all other discarded matter not normally present in sewage or industrial wastes. Also, the discarded matter not normally present in sewage or industrial waste.

Pass Through - The discharge which exits the Town of Hague Wastewater Treatment Plant (POTW) into waters of the State in quantities, which, alone or in conjunction with Discharges from other sources, is a cause of a violation of any requirement of the POTW's SPDES permit (including an increase in the magnitude or duration of a violation).

Permit - A temporary revocable written document allowing use of the POTW for specified wastes over a limited period of time, containing sampling locations and reporting frequencies, and requiring other actions as authorized by this Law.

Person - Any individual, public or private corporation, political subdivision, Federal, State, or local agency or entity, association, trust, estate or any other legal entity whatsoever.

pH - The logarithm (base 10) of the reciprocal of the weight of hydrogen ions, in gram moles per liter of solution. A pH value of 7.0, the pH scale midpoint, represents neutrality. Values above 7.0 represent alkaline conditions. Values below 7.0 represent acid conditions.

Phosphorus, total - See total phosphorus.

Pollutant - Any material placed into or onto the State's waters, lands and/or airs, which interferes with the beneficial use of that water, land and/or air by any living thing at any time.

Pollution - The man-made or man-induced alteration of the chemical, physical, biological, and/or radiological integrity of the State's waters, lands and/or airs resulting from the introduction of a pollutant into these media.

Pretreatment (Treatment) - The reduction of the amount of pollutants, the elimination of pollutants, or the alteration of the nature of pollutant properties in wastewater to a less harmful state prior to or in lieu of discharging or otherwise introducing such pollutants into a POTW. The reduction or alteration can be achieved by physical, chemical, or biological process, process changes, or by other means, except as prohibited by 40 CFR, Section 403.6 (D).

Pretreatment Requirements - Any substantive or procedural requirement related to

pretreatment, other than a National Pretreatment Standard imposed on an industrial user.

Pretreatment Standard or National Pretreatment Standard -Any Categorical Standard or Prohibitive Discharge Standard.

Priority Pollutants - The most recently revised or updated list, developed by the EPA, in accordance with the Act.

Prohibitive Discharge Standard - see National Prohibitive Discharge Standard.

Properly Shredded Garbage - The wastes from the preparation, cooking, and dispensing of food that have been shredded to such a degree that all particles will be carried freely under the flow conditions normally prevailing in public sewers, and with no particle having a dimension greater than one-half (1/2) inch in any dimension.

POTW Treatment Plant - That portion of the POTW designed to provide treatment to wastewater, and to treat sludge and residuals derived from such treatment.

Publicly Owned Treatment Works (POTW) - A treatment works, as defined by Section 212 of the Act, (33 U.S.C 1292), which is owned, in this instance, by Town of Hague . This definition includes any sewers and appurtenances that transport wastewater to the POTW treatment plant, but does not include pipes, sewers, or other conveyances not connected directly or indirectly to a facility providing treatment.

Receiving Waters - A natural watercourse or body of water (usually Waters of the State) into which treated or untreated sewage is discharged.

Records - Shall include, but not be limited to, any printed, typewritten, handwritten or otherwise recorded matter of whatever character (including paper or electronic media), including but not limited to, letters, files, memoranda, directives, notes and notebooks, correspondence, descriptions, telephone call slips, photographs, permits, applications, reports, compilations, films, graphs and inspection reports. For the purposes of this law, records shall mean records of and relating to waste generation, reuse and disposal, and shall include records of usage of raw materials.

Roof Drain - A drain installed to receive water collecting on the surface of a roof for disposal.

Septage - All liquids and solids in and removed from septic tanks, holding tanks, cesspools, or approved type of chemical toilets, including but not limited to those serving private residences, commercial establishments, institutions, and industries. Also sludge from small sewage treatment plants. Septage shall not have been contaminated with substances of concern or priority pollutants.

Septic Tank - A private domestic sewage treatment system consisting of an underground tank (with suitable baffling), constructed in accordance with any and/or all local and State

requirements.

Service Area of the POTW - The legally defined bounds of real property from which wastewater may be discharged into the POTW. The bounds shall be established, altered, changed, modified, reduced, enlarged, combined, or consolidated by action of the Town of Hague (Board, Council).

Sewage - A combination of the water-carried wastes from residences, business buildings, institutions, and industrial establishments, and such ground, surface, and storm water as may be inadvertently present. The admixture of sewage, as defined above, with industrial wastes and other wastes shall also be considered "sewage", within the meaning of this definition.

Sewage, Domestic (Domestic Wastes) - Liquid wastes from the non-commercial preparation, cooking, and handling of food, liquid wastes containing human excrement and similar matter from the sanitary conveniences in dwellings, commercial buildings, industrial buildings, and institutions, or liquid wastes from clothes washing and/or floor/wall washing. Therefore, domestic sewage includes both black water and grey water. (See Sewage, Sanitary.)

Sewage, Normal - Sewage, industrial wastes, or other wastes, which show, by analysis, the following characteristics:

- B.O.D. (Five Day) - 2090 lbs. per million gallons (250 milligrams per liter), or less.
 - Suspended Solids - 2500 lbs. per million gallons (300 milligrams per liter), or less.
 - Phosphorus - 125 lbs. per million gallons (15 milligrams per liter), or less
 - Ammonia - 250 lbs. per million gallons (30 milligrams per liter), or less.
 - Total Kjeldahl Nitrogen - 417 lbs. per million (50 milligrams per liter), or less.
 - Chlorine Demand - 209 lbs. per million gallons (25 milligrams per liter), or less.
 - Chemical Oxygen Demand - 2920 lbs. per million gallons (350 milligrams per liter), or less.
-
- Oil and Grease - 830 lbs. per million gallons (100 milligrams per liter), or less

In spite of satisfying one or more of these characteristics, if the sewage also contains substances of concern, it may not be considered normal sewage.

Sewage, Sanitary - Liquid wastes from the sanitary conveniences of dwellings (including apartment houses and hotels), office buildings, factories, or institutions, and free from storm water, surface water, industrial, and other wastes. (See Domestic Wastes.)

Sewage Treatment Plant (Water Pollution Control Plant) - see POTW Treatment Plant.

Sewage, Unusual Strength or Character - Sewage which has characteristics greater than those of Normal Sewage and /or which contains Substances of Concern.

Sewer - A pipe or conduit for carrying or transporting sewage.

Sewer, Combined - A sewer designed to receive and transport both surface runoff and sewage.

Sewer, Public - A sewer in which all abutting property owners have equal rights, and the use of which is controlled by the Town of Hague.

Sewer, Sanitary - A sewer which carries sewage, and to which storm, surface, and groundwaters are not intentionally admitted.

Sewer, Storm (Storm Drain) - A sewer which carries storm and surface waters and drainage, but excludes sewage and industrial wastewaters, other than cooling waters and other unpolluted waters.

Sewerage System (also POTW) - All facilities for collecting, regulating, pumping, and transporting wastewater to and away from the POTW treatment plant.

Sewerage Surcharge - The demand payment for the use of a public sewer and/or sewage treatment plant for the handling of any sewage, industrial wastes, or other wastes accepted for admission thereto in which the characteristics thereof exceed the maximum values of such characteristics in normal sewage. (See Volume Charge.)

Significant Industrial User - see User, Significant Industrial.

Significant Non-Compliance (SNC) - A User is in significant non-compliance if its violation(s) meet(s) one or more of the following criteria:

- Chronic violations of wastewater discharge limits, defined here as those, in sixty-six (66) percent or more of all of the measurements taken during a six-month period, which exceed (by any magnitude) the daily maximum limit or average limit for the same pollutant parameter;
- Technical Review Criteria (TRC) violations, defined here as those, in which thirty-three (33) percent or more of all of the measurements for each pollutant parameter taken during a six-month period, which equal or exceed the product of the daily maximum limits multiplied by the applicable TRC (TRC = 1.4 for BOD, TSS, fats, oil and grease; TRC = 1.2 for all other pollutants);
- Any other violation of a pretreatment effluent limit (daily maximum or long-term average) that the Wastewater Treatment Plant Operator determines has caused, alone or in combination with other discharges, interference or pass through (including endangering the health of POTW personnel or the general public);
- Any discharge of a pollutant that has caused imminent endangerment to human health, welfare or to the environment or has resulted in the Town's exercise of its emergency authority under Article 11 of this Law;
- Failure to meet, within 90 days after the schedule date, a compliance schedule

- milestone contained in a local control mechanism or enforcement order for starting construction, completing construction, or attaining final compliance;
- Failure to provide, within 30 days after the due date, required reports such as baseline monitoring reports, 90-day compliance reports, periodic self-monitoring reports, and reports on compliance with compliance schedules;
 - Failure to report accurately any non-compliance;
 - Any other violation which the Wastewater Treatment Plant Operator determines will adversely affect the implementation or operation of the local pretreatment program.

Slug - A substantial deviation from normal rates of discharge or constituent concentration (see normal sewage) sufficient to cause interference. In any event, a discharge which, in concentration of any constituent or in quantity of flow, that exceeds, for any period of duration longer than fifteen (15) minutes, more than five (5) times the average twenty-four (24) hour concentration or flow during normal user operations, shall constitute a slug.

Standard Industrial Classification (SIC) - A classification pursuant to the Standard Industrial Classification Manual issued by the Executive Office of the President, Office of Management and Budget, 1972, and subsequent revisions.

Standard Methods - Procedures contained in the latest edition of "Standard Methods for the Examination of Water and Wastewater", published by the American Public Health Association, procedures established by the Administrator, pursuant to Section 304 (G) of the Act and contained in 40 CFR, Part 136, and amendments thereto. (If 40 CFR, Part 136 does not include a sampling or analytical technique for the pollutant in question, then procedures set forth in EPA publication, "Sampling and Analysis Procedures for Screening of Industrial Effluents for Priority Pollutants", April 1977, and amendments thereto, shall be used.), any other procedure approved by the Administrator, or any other procedure approved by the Wastewater Treatment Plant Operator, whichever is the most conservative.

State - State of New York.

State's Waters - See Waters of the State.

Storm Water - Any flow occurring during or following any form of natural precipitation; also the flow resulting there from.

Substances of Concern - Those compounds which the New York State Department of Environmental Conservation has determined may be harmful to man or the environment.

Sump Pump - A mechanism used for removing water from a sump or wet well.

Suspended Solids - The result obtained, using an approved laboratory procedure, to determine the dry weight of solids, in a sample, that either float on the surface of, or are in suspension, or are settleable, and can be removed from the sample by filtration, expressed in milligrams per liter.

Total Kjeldahl Nitrogen (TKN) - The result obtained, using an approved laboratory procedure, to determine the quantity of ammonia in a sample and released during the acid digestion of organic nitrogen compounds, expressed as milligrams of nitrogen per liter.

Total Phosphorus - The result obtained, using an approved laboratory procedure, to determine the total quantity of orthophosphate, in a sample of wastewater, following the hydrolysis of phosphorus compounds, expressed as milligrams of phosphorus per liter of sample.

Town - The Town of Hague, as incorporated on April 6, 1807.

Toxic Substances - Any substance, whether gaseous, liquid, or solid, that when discharged to a public sewer in sufficient quantities may be hazardous to POTW operation and maintenance personnel, tend to interfere with any biological sewage treatment process, or to constitute a hazard to recreation in the receiving waters, due to the effluent from a sewage treatment plant or overflow point. Any pollutant or combination of pollutants listed as toxic in regulations promulgated by the EPA under provisions of CWA 307 (A), or other Acts.

User - Any person who contributes, causes, or permits the contribution of wastewater into the POTW.

User, Existing - A discharger to the POTW who is discharging on or before the effective date of this Law.

User, Industrial - A discharger to the POTW who discharges non-domestic wastewaters.

User, New - A discharger to the POTW who initiates discharge after the effective date of this Law.

User, Significant Industrial (SIU) - An industrial user of the Town of Hague POTW who is:

- Subject to National Categorical Pretreatment Standards promulgated by the EPA,
- Having substantial impact, either singly or in combination with other industries, on the operation of the treatment works,
- Using, on an annual basis, more than 10,000 lbs or 1,000 gallons of raw material containing priority pollutants and/or substances of concern and discharging a measurable quantity of these pollutants to the sewer system,
- Discharging more than five percent (5%) of the flow or load of conventional pollutants received by the POTW treatment plant.

*Note: A user discharging a measurable quantity of a pollutant may be classified as non-significant if, at the influent to the POTW treatment plant, the pollutant is not detectable.

Volume Charge (User Charge) - The demand sewer use charge which is based, in part or wholly, on the volume of normal sewage discharged into the POTW (there may be

surcharges, as provided for in Article 12). The volume charge shall be based on a specific cost per 100 cubic feet or per 1,000 gallons. The specific charge shall be subject to approval by the Town of Hague Board. The moneys so obtained shall be used for current operation and maintenance, for retirement of bonded indebtedness, and for funding of capital projects, of the POTW. The basis of volume charge calculations shall be made available to the public, on demand, as provided in Article 13. The volume charge shall be recalculated annually, as well as the surcharge rates.

Wastewater - The liquid and water-carried industrial or domestic wastewaters from dwellings, commercial establishments, industrial facilities, and institutions, together with any groundwater, surface water, and storm water that may be present, whether treated or untreated, which is contributed into or permitted to enter the POTW.

Wastewater Discharge Permit - A permit as set forth in Article 10 of this Law.

Wastewater Treatment Plant Operator - That individual nominated by the Town of Hague Supervisor, and confirmed by the Town of Hague Board as the Wastewater Treatment Plant Operator. Such an individual shall be licensed in the State, and otherwise qualified to oversee wastewater collection, conveyance and POTW operations. This definition shall also include his authorized deputy, agent, or representative.

Wastewater, Unusual Strength or Character - see Sewage, Unusual Strength or Character.

Zoning Enforcement Officer - That individual nominated by the Town of Hague Supervisor, and confirmed by the Town of Hague Board as the Zoning Enforcement Officer. This definition shall also include his authorized deputy, agent, or representative.

Waters of the State (State's Waters) - All streams, lakes, ponds, marshes, water courses, waterways, wells, springs, reservoirs, aquifers, irrigation systems, drainage systems, and all other bodies or accumulations of water, surface or underground, natural or artificial, public or private, which are contained within, flow through, or border upon the State or any portion thereof.

Section 202 - Abbreviations

The following abbreviations shall have the designated meanings:

ANSI - American National Standards Institute
ASTM - American Society for Testing and Materials
AWWA - American Water Works Association
BOD - Biochemical Oxygen Demand
CFR - Code of Federal Regulations
CPLR - Code of Public Law and Rules
COD - Chemical Oxygen Demand
EPA - Environmental Protection Agency

L - Liter
Mg - Milligram
Mg/l - Milligrams per liter
NCPI - National Clay Pipe Institute
NPDES - National Pollutant Discharge Elimination System
NYSDEC - New York State Department of Environmental Conservation
NYSDOH - New York State Department of Health
NYSDOT - New York State Department of Transportation
P - Total Phosphorus
PSI - Pounds per Square Inch
POTW - Publicly Owned Treatment Works
PPM - Parts per Million, weight basis
SIC - Standard Industrial Classification
SPDES - State Pollutant Discharge Elimination System
SWDA - Solid Waste Disposal Act, 42 U.S.C. 690 L, et seq.
U.S.C. - United State Code of Laws
USEPA - United State Environmental Protection Agency
TSS - Total Suspended Solids
Section 203 - Undefined Terms

Terms not defined in this article, or terms found to be ambiguous or improperly defined in this article, shall be defined by the Act, or Regulations, pursuant thereto.

Article 3

Use of Public Sewers Required

Section 301 - Waste Disposal Unlawful
Section 302 - Connecting Private Sewage System to Storm Sewer Unlawful
Section 303 - Discharge of Sewage into Well Prohibited
Section 304 - Wastewater Discharge Unlawful
Section 305 - Building Permit Allowed Only When Approved Wastewater Disposal Available
Section 306 - Private Wastewater Disposal Unlawful
Section 307 - Connection to Public Sewer Required
Section 308 - Limitation on Use of Public Sewers
Section 309 - Wastewater from Outside the POTW Service Area - Inter-municipal Agreements
Section 310 - Moratorium
Section 311 - Basis of Sewer Use Requirement
Section 301 - Waste Disposal Unlawful

It shall be unlawful for any person to place, deposit, or permit to be deposited, in any unsanitary manner, on public or private property, within the Town of Hague or in any area

under the jurisdiction of the said municipality, any human or animal excrement, garbage, or objectionable waste. Also, no person shall discharge domestic sewage onto the surface of the ground or discharge it in a way that permits it to come to the surface of the ground.

Section 302 - Connecting Private Sewage system to Storm Sewer Unlawful

No person shall connect a private sewage system so that sewage flows into a storm sewer or into a drain intended exclusively for storm water.

Section 303 - Discharge of Sewage into Well Prohibited

No person shall discharge sewage into a well.

Section 304 - Wastewater Discharge Unlawful

It shall be unlawful to discharge to any natural outlet, within Town of Hague, or in any area under the jurisdiction of the said municipality, any wastewater or other polluted waters, except where suitable treatment has been provided in accordance with subsequent provisions of this Law.

Section 305 - Building Permit Allowed Only When Approved Wastewater Disposal Available

No property owner, builder, or developer shall be issued a building permit for a new dwelling or structure requiring sanitary facilities unless a suitable and approved method of wastewater disposal, conforming to this Law, is available. All housing construction or building development which takes place after this Law is enacted shall provide for an approved system of sanitary sewers.

Section 306 - Private Wastewater Disposal Unlawful

Except as hereinafter provided, it shall be unlawful to construct or maintain any privy, privy vault, cesspool, septic tank, or other facility intended or used for disposal of wastewater within the Sewer District.

Section 307 - Connection to Public Sewer Required

The owner(s) of all houses, buildings, or properties used for human occupancy, employment, recreation, or other purposes, situated within the Town of Hague, Sewer District and any extension thereof, is hereby required, at the owner's expense to install suitable sanitary facilities therein, and to connect such facilities directly with the proper public sewer, in accordance with the provisions of this law, within ninety (90) days after official notice to do so, provided that said public sewer is within one hundred (100) feet (30.5 meters) of the property line.

Section 308 - Limitation on Use of Public Sewers

The use of the Town of Hague public sewers shall be strictly limited and restricted, except as provided in Section 307, to receive and accept the discharge of sewage and other wastes, including industrial wastes generated on or discharged from real property within the bounds of the Service Area of the POTW.

Section 309 - Wastewater from Outside the POTW Service Area - Inter-municipal Agreements

The Town of Hague Board, on the recommendation of the Wastewater Treatment Plant Operator, shall have the authority to enter into agreements to accept sewage and other wastes, including industrial wastes, generated by or discharged from persons outside the service area of the POTW.

If the person is a municipality, that municipality shall have enacted a Sewer Use Law as restrictive on the discharge of sewage and other wastes as the restrictions contained in this Law.

If the person is not a municipality the acceptance shall be made only with the expressed written consent of the Wastewater Treatment Plant Operator (the issuance of a permit) setting forth the terms and conditions of such a acceptance.

Section 310 - Moratorium

At the recommendation of the Wastewater Treatment Plant Operator, who determines that:

- one or more segments of the POTW is exceeding its hydraulic capacity at any time
- any specific purpose of this Law is being violated

The Town of Hague Board shall have the authority to limit or deny new connections to the POTW until the conditions leading to the moratorium are corrected. Such correction may be by:

- construction of new facilities
- enlarging existing facilities
- correction of inflow and infiltration
- cleaning and repairing of existing facilities

Section 311 - Basis of Sewer Use Requirement

All requirements, directives, and orders calling for mandatory use of the sewers, within the Service Area of the POTW, for the proper discharge of sewage and other wastes, including industrial wastes, shall be established and given by the Town of Hague Board, NYSDEC, USEPA, and/or other such State or Federal agencies, which have enforcement powers.

Article 4

New Sewers or Sewer Extensions

- Section 401 - Proper Design
- Section 402A - New Sewers Subject to Approval, Fees, Inspection, Testing, and Reporting
- Section 402B - Plans, Specification, and Pipe Test Results Required
- Section 403A - Sewer Pipe
- Section 403B - Safety and Load Factors
- Section 403C - Sewer Pipe installation
- Section 403D - Cleanout Installation
- Section 404 - Manholes and Manhole Installation
- Section 405A - Infiltration/Exfiltration Testing
- Section 405B - Test Section
- Section 405C - Test Period
- Section 405D - Pipe Lamping
- Section 405E - Deflection Testing
- Section 405F - Air Testing Alternative
- Section 405G - Vacuum Testing Alternative
- Section 406A - Force Mains
- Section 406B - Force Main Testing
- Section 407 - Final Acceptance and Warranty/Surety
- Section 408 - Liability Insurance Coverage During Construction Period

Section 401 - Proper Design

New sanitary sewers and all extensions to sanitary sewers owned and operated by the Town of Hague shall be designed, by a professional licensed to practice sewer design in the State, in accordance with the Recommended Standards for Sewage Works, as adopted by the Great Lakes - Upper Mississippi River Board of State Sanitary Engineers ("Ten State Standards"), and in strict conformance with all requirements of the NYSDEC. Plans and specifications shall be submitted to, and written approval shall be obtained from the Zoning Enforcement Officer, the NYSDOH, and the NYSDEC, before initiating any construction. The design shall anticipate and allow for flows from all possible future extensions or developments within the immediate drainage area.

If, however, there is inadequate capacity in any sewer which would convey the wastewater or if there is insufficient capacity in the POTW treatment plant to treat the wastewater properly, the application shall be denied. Sewer line and POTW treatment plant current use shall be defined as the present use and the unutilized use which has been committed, by resolution, to other users by the Town of Hague Board.

Section 402 A - New Sewers Subject to Approval, Fees, Inspection, Testing, and Reporting

When a property owner, builder, or developer proposes to construct sanitary sewers or extensions to sanitary sewers in an area proposed for subdivision, the plans, specifications, and method of installation shall be subject to the approval of the Wastewater Treatment Plant Operator, and the NYSDOH, in accordance with Section 501. Said property owner, builder, or developer shall pay for the entire installation, including a proportionate share of the treatment plant, intercepting or trunk sewers, pumping stations, force mains, and all other Town of Hague expenses incidental thereto. Each street lateral shall be installed and inspected pursuant to Article 6, and inspection fees shall be paid by the applicant prior to initiating construction. Design and installation of sewers shall be as specified in Section 503, and in conformance with Paragraphs 3 through 6 of ASTM Specification C-12. The installation of the sewer shall be subject to periodic inspection by the Wastewater Treatment Plant Operator, without prior notice. The Wastewater Treatment Plant Operator shall determine whether the work is proceeding in accordance with the approved plans and specifications, and whether the completed work will conform with the approved plans and specifications. The sewer, as constructed, must pass the infiltration test (or the exfiltration test, with prior approval), required in Section 505, before any building lateral is connected thereto. The Wastewater Treatment Plant Operator shall be notified 30 days in advance of the start of any construction actions so that such inspection frequencies and procedures as may be necessary or required, may be established. No new sanitary sewers will be accepted by the Town of Hague Board until such construction inspections have been made so as to assure the Town of Hague Board of compliance with this Law and any amendments or additions thereto. The Wastewater Treatment Plant Operator has the authority to require such excavation as necessary to inspect any installed facilities if the facilities were covered or otherwise backfilled before they were inspected so as to permit inspection of the construction. The Wastewater Treatment Plant Operator shall report all findings of inspections and tests to the Town of Hague Board.

Section 402 B - Plans, Specification, and Pipe Test Results Required

Plans, specifications, and methods of installation shall conform to the requirements of this Article. Components and materials of wastewater facilities not covered in this Law, such as pumping stations, lift stations, or force mains shall be designed in accordance with Section 501, and shall be clearly shown and detailed on the plans and specifications submitted for approval. Force main details are covered in Section 506. When requested, the applicant shall submit, to the Wastewater Treatment Plant Operator and to the NYSDOH, all design calculations and other pertinent data to supplement review of the plans and specifications. Results of manufacturer's tests on each lot of pipe delivered to the job site shall also be furnished, upon request.

Section 403 A - Sewer Pipe

1) Sewer pipe material shall be:

- Reinforced Concrete Pipe (Note that non-reinforced concrete pipe shall not be used.)
 - Portland cement shall conform to ASTM C-150 Type II.

- The pipe and specials shall conform to ASTM Specification C-76.
 - The reinforcing wire cage shall conform to ASTM Specification A 15, A 82, or A 185, as appropriate.
 - Entrained air shall be 5.0% to 9.0% by ASTM C-890.
 - Water absorption and three-edge bearing tests shall conform to ASTM Specification C-497.
 - Gaskets shall conform to Sections 3.3 and 3.4 of AWWA Specification C-302.
- Cast Iron Pipe - Extra Heavy
 - Pipe, fittings, and specials shall conform to the requirements of ASTM Specification A-74 or ANSI A-21.11.
 - Gaskets shall conform to ASTM Specification C-564.
- Polyvinyl Chloride (PVC) Pipe - Heavy Wall
 - Pipe shall be made from Class 12454-B materials or better in accordance with ANSI/ASTM Specification D-1784.
 - Pipe and accessories shall conform to the requirements of the following, with a minimum pipe stiffness of 46.
 - PSI at a maximum deflection of five percent (5%).
 - ANSI/ASTM D 3034 (4" - 15")
 - ASTM F 679 Type I (18" - 27")
- Ductile Iron Pipe
 - Pipe, fittings, and specials shall be manufactured in accordance with ASTM Specification A-746.
 - Pipe shall have a minimum thickness of Class 50.
 - Fittings shall conform to ANSI Specification A-21.11 and have a minimum pressure class rating of 150 PSI.
 - All pipe and fittings shall be cement mortar lined in accordance with ANSI Specification A-21.4 at twice the specified thickness, and have an internal and external bituminous seal coating.
 - Closure pieces shall be jointed by means of a mechanical coupling of the cast sleeve type.

- High Density Polyethylene Pipe – (HDPE) SDR 11 wall thickness.
 - Pipe shall conform to the current requirements of PE 3408 and meet the requirements of ASTM Specification F714, with a co-extruded integral layered shell colored green to identify the pipe as a sewer line.
 - Joints shall be butt fusion welded.
 - HDPE pipe shall be used only for low-pressure sewers and laterals.
- Acrylonitrile-Butadiene-Styrene (ABS) Pipe
 - Pipe and fittings shall conform to the requirements of ASTM Specification D2661.
- Other pipe materials
 - Other pipe materials require prior written approval of the Zoning Enforcement Officer before being installed.
 - § the minimum internal pipe diameter shall be eight (8) inches for gravity sewers and two (2) inches for low-pressure sewers.
 - § Joints for the selected pipe shall be designed and manufactured such that "O" ring gaskets of the "snap-on" type are used.
 - § Gaskets shall be continuous, solid, natural or synthetic rubber, and shall provide a positive compression seal in the assembled joint, such that the requirements of Section 505 are met.
 - § Joint preparation and assembly shall be in accordance with the manufacturer's recommendations.
 - § Wye branch fittings, as approved by the Wastewater Treatment Plant Operator, shall be installed, for connection of street laterals, in accordance with Section 606.

Section 403 B - Safety and Load Factors

Selection of pipe class shall be predicated on the following criteria:

Safety factor - 1.5

Load factor - 1.7

Weight of soil - 120 lbs/cu. ft.

Wheel loading - 16,000 lbs.

Utilizing the foregoing information, design shall be made as outlined in Chapter IX of the Water Pollution Control Federation Manual of Practice No. 9, latest edition, "Design and Construction of Sanitary and Storm Sewers", and the pipe shall have sufficient structural strength to support all loads to be placed on the pipe, with a safety factor as specified above.

PVC, and HDPE pipe shall not be encased in concrete due to their different coefficients of linear thermal expansion.

Section 403 C - Sewer Pipe Installation

(1) Local utilities shall be contacted to verify construction plans and to make arrangements to disconnect all utility services, where required to undertake the construction work. The utility services shall later be reconnected. The work shall be scheduled so that there is minimum inconvenience to local residents. Residents shall be provided proper and timely notice regarding disconnection of utilities.

(2) The construction right-of-way shall be cleared only to the extent needed for construction. Clearing consists of removal of trees which interfere with construction, removal of underbrush, logs, and stumps, and other organic matter, removal of refuse, garbage, and trash, removal of ice and snow, and removal of telephone and power poles, and posts. Any tree which will not hinder construction shall not be removed, and shall be protected from damage by any construction equipment. Debris shall not be burned, but hauled for disposal in an approved manner.

(3) The public shall be protected from personal and property damage as a result of the construction work.

(4) Traffic shall be maintained at all times in accordance with applicable highway permits. Where no highway permits are required, at least 1/2 of a street shall be kept open for traffic flow.

5) Erosion control shall be performed throughout the project to minimize the erosion of soils onto lands or into waters adjacent to or affected by the work. Erosion control can be effected by limiting the amount of clearing and grubbing prior to trenching, proper scheduling of the pipe installation work, minimizing time of open trench, prompt grading and seeding, and filtration of drainage.

(6) The trench shall be excavated only wide enough for proper installation of the sewer pipe, manhole, and appurtenances. Allowances may be made for sheeting, de-watering, and other similar actions to complete the work. Roads, sidewalks, and curbs shall be cut, by sawing or by other methods as approved by the Wastewater Treatment Plant Operator, before trench excavation is initiated.

(7) Under ordinary conditions, excavation shall be by open cut from the ground surface. However, tunneling or boring under structures other than buildings may be permitted. Such

structures include crosswalks, curbs, gutters, pavements, trees, driveways, and railroad tracks.

(8) Open trenches shall be protected at all hours of the day with barricades, as required.

(9) Trenches shall not be open for more than 30 feet in advance of pipe installation nor left unfilled for more than 30 feet in the rear of the installed pipe, when the work is in progress, without permission of the Wastewater Treatment Plant Operator. When work is not in progress, including over night, weekends, and holidays, the trench shall be backfilled to ground surface.

(10) The trench shall be excavated approximately six (6) inches deeper than the final pipe grade. When unsuitable soils are encountered, these shall be excavated to a maximum depth of 2-1/2 feet below the final pipe invert grade and replaced with select materials.

(11) Ledge rock, boulders, and large stones shall be removed from the trench sides and bottom. The trench shall be over-excavated at least 12 inches for five (5) feet, at the transition from rock bottom to earth bottom, centered on the transition.

(12) Maintenance of grade, elevation, and alignment shall be done by some suitable method or combination of methods.

(13) No structure shall be undercut unless specifically approved by the Wastewater Treatment Plant Operator.

(14) Proper devices shall be provided, and maintained operational at all times, to remove all water from the trench as it enters. At no time shall the sewer line be used for removal of water from the trench.

(15) To protect workers and to prevent caving, shoring and sheeting shall be used, as needed. Caving shall not be used to backfill the trench. Sheeting shall not be removed but cut off no lower than one foot above the pipe crown nor no higher than one foot below final grade, and left in the trench, during backfill operations.

(16) The pipe barrel shall be supported, along its entire length, on a minimum of six (6) inches of crusher run max. 1/2-inch stone free of organic material. This foundation shall be firmly tamped in the excavation.

(17) Bell holes shall be hand excavated, as appropriate.

(18) Pipe shall be laid from low elevation to high elevation. The pipe bell shall be up gradient; the pipe spigot shall be down gradient.

(19) Joint preparation and assembly shall be in accordance with the manufacturer's written instructions.

(20) The grade and alignment shall be checked and made correct. The pipe shall be in straight alignment. Any negotiation of curves shall be at manholes, except when site conditions require alternative pipe laying procedures. These alternative procedures, including bending the pipe barrel, deflecting the joint, and using special fittings, shall require prior written approval of the plans and also written confirmation approval of need by the Wastewater Treatment Plant Operator after examination of the site conditions.

(21) When a smaller sewer joins a larger one the invert of the larger sewer shall be lowered sufficiently to maintain the same hydraulic gradient. An approximate method which may be used for securing this result is to place the 0.8 depth of both sewers at the same elevation.

(22) Crushed stone shall be placed over the laid pipe to a depth of at least six (6) inches. The embedment of thermoplastic pipe shall be in accordance with ASTM D2321 using class 1A or 1B backfill materials. Care shall be exercised so that stone is packed under the pipe haunches. Care shall be exercised so that the pipe is not moved during placement of the crushed stone.

(23) The migration of fines from surrounding backfill or native soils shall be restricted by gradation of embedment materials or by use of suitable filter fabric.

(24) The remaining portion of the trench above the pipe embedment shall be backfilled in one-foot lifts which shall be firmly compacted. Compaction near/under roadways, driveways, sidewalks, and other structures shall be to 95 % of the maximum moisture-density relationship, as determined by ASTM Specification D 698, Method D. Ice, snow, or frozen material shall not be used for backfill.

Section 403 D - Cleanout Installation

(1) Cleanouts for low pressure sewers shall be placed at intervals of approximately 400 to 500 feet, at major changes of direction, where one collection main joins another main and at the upstream end of each main branch.

(2) The design of the cleanouts shall be as approved by the Wastewater Treatment Plant Operator.

Section 404 - Manholes and Manhole Installation

(1) Design of all manholes shall be submitted to the Wastewater Treatment Plant Operator and shall receive approval prior to placement.

(2) Manholes shall be placed where there is a change in slope or alignment, and at intervals not exceeding 400 linear feet except as authorized by the Wastewater Treatment Plant Operator.

(3) Manhole bases shall be constructed or placed on a minimum of six (6) inches of crusher run max. 1/2-inch stone free of organic materials.

(4) Manhole bases shall be constructed of 4,000 psi (28 day) concrete 8 inches thick, or shall

be precast bases properly bedded in the excavation. Field constructed bases shall be monolithic, properly reinforced, and extend at least 6 inches beyond the outside walls of lower manhole sections. Precast manhole bases shall extend at least 6 inches beyond the outside walls of lower manhole sections.

(5) Manholes shall be constructed using precast minimum 4 foot diameter concrete manhole barrel sections, and an eccentric top section, conforming to ASTM Specification C-478, with the following exceptions on wall thickness:

Manhole Diameter (Feet)	Wall Thickness (Inches)
4	5
5	6
6	7
6 1/2	7 1/2
7	8
8	9

All sections shall be cast solid, without lifting holes.

Flat top slabs shall be a minimum of 8 inches thick and shall be capable of supporting a H-20 loading.

(6) All joints between sections shall be sealed with an "O" ring rubber gasket, meeting the same specifications as concrete pipe joint gaskets, or butyl joint sealant completely filling the joint.

(7) All joints shall be sealed against infiltration. All metal parts shall be thickly coated with bitumastic or elastomeric compound to prevent corrosion.

(8) Steps or ladder rungs shall be installed at 12-inch spacing on the inside manhole walls. Steps shall be copolymer polypropylene encased 1/2-inch diameter grade 60 reinforcing steel, with a non-skid tread and lugged ends.

(9) No holes shall be cut into the manhole sections closer than 6 inches from joint surfaces.

10) Manholes which extend above grade shall not have an eccentric top section. The top plate shall be large enough to accommodate the cover lifting device and the cover.

(11) The elevation of the top section shall be such that the cover frame top elevation is 0.5 foot above the 100-year flood elevation (in a field), 0.5 foot above a lawn elevation, or at finished road or sidewalk grade.

(12) When located in a traveled area (road or sidewalk), the manhole frame and cover shall be heavy-duty cast iron. When located in a lawn or in a field, the manhole frame and cover

may be light duty cast iron. The cover shall be 30 inches, minimum, in diameter. The maximum weight of the cover shall be 150 lbs. The mating surfaces shall be machined, and painted with tar pitch varnish. The cover shall not rock in the frame. Infiltration between the cover and frame shall be prevented by proper design and painting. Covers shall have "Town of Hague Sanitary Sewer" cast into them. Covers shall have lifting holes suitable for any lifting/jacking device. The lifting holes shall be designed so that infiltration is prevented.

(13) A drop of at least 0.1 foot shall be provided between incoming and outgoing sewers on all junction manholes and on manholes with bends greater than 45 degrees.

(14) Inverts and shelves/benches shall be placed after testing the manholes and sewers.

(15) Benches shall be level and slope to the flow channel at about 1 inch per foot.

(16) The minimum depth of the flow channel shall be the nominal diameter of the smaller pipe. The channel shall have a steel trowel finish. The flow channel shall have a smooth curvature from inlet to outlet.

(17) Manhole frames, installed at grade, shall be set in a full bed of mortar with no less than 6-inches of precast concrete grade rings underneath to allow for later elevation adjustment. The total number of grade rings shall not exceed 12 inches in height, however, in no event shall more than 3 grade rings be used.

(18) Manholes which extend above grade, shall have the frames cast into the manhole top plate. The top plate shall be securely anchored to the manhole barrel, by a minimum of six 1/2-inch corrosion resistant anchor bolts, to prevent overturning when the cover is removed. The anchor bolts shall be electrically isolated from the manhole frame and cover.

(19) Internal drop pipes and fittings shall be PVC plastic sewer pipe in compliance with ASTM D2241. Corrosion resistant stainless steel anchors and brackets shall be used to attach the drop pipe to the inside surface of the manhole barrel.

Section 405 A - Infiltration/Exfiltration Testing

All sanitary sewers or extensions to sanitary sewers, including manholes, shall satisfy requirements of a final infiltration test before they will be approved and wastewater flow permitted by the Town of Hague. The infiltration rate shall not exceed 25 gallons per 24 hours per mile per nominal diameter in inches. An exfiltration test may be substituted for the infiltration test; the same rate shall not be exceeded. The exfiltration test shall be performed by the applicant, under the supervision of the Wastewater Treatment Plant Operator, who shall have the responsibility for making proper and accurate measurements required. The exfiltration test consists of filling the pipe with water to provide a head of at least 5 feet above the top of the pipe or 5 feet above groundwater, whichever is higher, at the highest point under test, and then measuring the loss of water, from the pipe section under test, by the amount of water which must be added to maintain the original level. However, under no circumstances shall the head at the downstream manhole exceed ten (10) feet or fill to

within six (6) inches of the top of the downstream manhole. Should this condition prevail, the testing methods in Sections 504 F and/or 504 G shall be utilized. In this test, the test section must remain filled with water for at least 24 hours prior to taking any measurements. Exfiltration shall be measured by the drop of water level in a standpipe with a closed bottom end, or in one of the sewer manholes serving the test section. When a standpipe and plug arrangement is used in the upper manhole in the test section, there shall be some positive method for releasing entrapped air prior to taking any measurements.

Section 405 B - Test Section

The test section shall be as ordered or as approved, but in no event longer than 1,000 feet. In the case of sewers laid on steep grades, the test length may be limited by the maximum allowable internal pressure on the pipe and joints at the lower end of the test section. For purposes of determining the leakage rate of the test section, manholes shall be considered as sections of 48-inch diameter pipe, 5 feet long. The maximum allowable leakage rate for such a section is 1.1 gallons per 24 hours. If leakage exceeds the allowable rate, then necessary repairs or replacements shall be made, and the section retested.

Section 405 C - Test Period

The test period, during which the test measurements are taken, shall not be less than two (2) hours.

Section 405 D - Pipe Lamping

Prior to testing, the section shall be lamped. Any length of pipe out of straight alignment shall be realigned.

Section 405 E - Deflection Testing

Also prior to testing, all plastic pipe, in the test section, shall be tested for deflection. Deflection testing shall involve the pulling of a rigid ball or mandrel, whose diameter is 95 percent of the pipe inside diameter, through the pipe. Any length of pipe with a deflection greater than 5 percent shall be replaced. The test section shall be flushed just prior to deflection testing. The test shall not be performed with a mechanical pulling device.

Section 405 F - Low Pressure Air Testing Alternative

In lieu of hydrostatic testing (exfiltration or infiltration), low pressure air testing may be employed. Low-pressure air tests shall conform to ASTM Specification C 828. All sections to be tested shall be cleaned and flushed, and shall have been backfilled, prior to testing. Air shall be added until the internal pressure of the test section is raised to approximately 4.0 PSIG. The air pressure test shall be based on the time, measured in seconds, for the air pressure to drop from 3.5 PSIG to 2.5 PSIG.

Acceptance is based on limits tabulated in the "Specification Time Required for a 1.0 PSIG Pressure Drop" in the Uni-Bell PVC Pipe Association "Recommended Practice For Low-

Pressure Air Testing of Installed Sewer Pipe".

Before pressure is applied to the line all connections shall be firmly plugged. Before the test period starts, the air shall be given sufficient time to cool to ambient temperature in the test section.

If the test section is below groundwater, the test pressure shall be increased by an amount sufficient to compensate for groundwater hydrostatic pressure, however, the test pressure shall not exceed 10 PSI, or a lower pressure as required by the Wastewater Treatment Plant Operator.

The pressure test gauge shall have been recently calibrated, and a copy of the calibration results shall be made available to the Wastewater Treatment Plant Operator prior to testing.

Section 405 G - Vacuum Testing Alternative

In lieu of hydrostatic testing (exfiltration or infiltration), vacuum testing may be employed for testing of sewer lines and manholes. Sewer lines and manholes shall be tested separately. All sewer lines to be tested shall be cleaned and flushed, and shall have been backfilled, prior to testing. The vacuum test shall be based on the time, measured in seconds, for the vacuum to decrease from 10 inches of mercury to 9 inches of mercury for manholes, and from 7 inches of mercury to 6 inches of mercury for sewers.

Acceptance of manholes is based on the following:

Manhole Depth	Manhole Diameter	Time to Drop 1 inch Hg (10"to9")
10 ft or less	4 ft	120 seconds
10 ft to 15 ft	4 ft	150 seconds
15 ft to 25 ft	4 ft	180 seconds

For 5 ft diameter manholes, add 30 seconds to the times above.

For 6 ft diameter manholes, add 60 seconds to the times above.

If the test on the manhole fails (the time is less than that tabulated above), necessary repairs shall be made and the vacuum test repeated, until the manhole passes the test.

Acceptance of sewers (7" Hg to 6" Hg) is based on the time tabulated in the "Specification Time Required for a 0.5 PSIG Pressure Drop" in the Uni-Bell PVC Pipe Association "Recommended Practice For Low-Pressure Air Testing of Installed Sewer Pipe".

The vacuum test gauge shall have been recently calibrated, and a copy of the calibration results shall be made available to the Wastewater Treatment Plant Operator prior to testing.

Section 406A - Force Mains

Force mains serving sewage lifting devices, such as grinder pumps and pump stations, shall be designed in accordance with Section 501. Additional design requirements are:

(1) Force main pipe material shall be:

(a) Ductile Iron Pipe

Pipe shall conform to ANSI A21.51. The minimum wall thickness shall be Class 52 (ANSI A21.50). The pipe shall be clearly marked with either "D" or "DUCTILE". Fittings shall conform to ANSI A21.10.

Pipe and fittings shall be furnished with push-on joints conforming to ANSI A21.11.

Pipe and fittings shall be cement mortar lined and have an internal and external bituminous seal coating.

(b) Polyvinyl Chloride (PVC) Plastic Pipe

Pipe shall conform to ASTM D2241. Materials used in the manufacture of PVC pipe shall meet ASTM c1784. The minimum wall thickness shall be SDR-21. Fittings shall conform to ASTM D2241. Joints and gaskets shall conform to ASTM D2241, D1869, and F477.

(c) High Density Polyethylene Pipe – (HDPE) SDR 11 wall thickness.

Pipe shall conform to the current requirements of PE 3408 and meet the requirements of ASTM Specification F714, with a co-extruded integral layered shell colored green to identify the pipe as a sewer line.

Joints shall be butt fusion welded.

HDPE pipe shall be used only for low-pressure sewers and laterals.

(d) Other pipe materials

Other pipe materials require prior written approval of the Wastewater Treatment Plant Operator before being installed.

(2) Trenching, bedding, and backfilling shall be in accordance with Section 503 C.

(3) Joint preparation and assembly shall be in accordance with the manufacturer's written instructions.

(4) Anchorages, concrete blocking, and/or mechanical restraint shall be provided when there

is a change of direction of 7-1/2 degrees or greater.

(5) Drain valves shall be placed at low points.

(6) Automatic air relief valves shall be placed at high points and at 400 ft intervals, on level force main runs.

(7) Air relief and drain valves shall be suitably protected from freezing.

(8) When the daily average design detention time, in the force main, exceeds 20 minutes, the manhole and sewer line receiving the force main discharge or the sewage shall be treated so that corrosion of the manhole and the exiting line are prevented. The corrosion is caused by sulfuric acid biochemically produced from hydrogen sulfide anaerobically produced in the force main.

(9) The force main shall terminate, in the receiving manhole, at a PVC plastic sewer pipe "T". The vertical arms of the "T" shall be twice the diameter of the force main. The upper arm shall be at least 4 feet long; the lower arm shall terminate in a PVC plastic sewer pipe 90-degree elbow in a flow channel directed to the manhole exit pipe. The "T" and its arms shall be securely fastened to the inside surface of the manhole wall using corrosion resistant anchors.

Section 406B - Force Main Testing

All force mains shall be subjected to hydrostatic pressure of 150 percent of the normal operating pressure. The duration of the test, at pressure, shall be at least 2 hours. Before conducting the test, the pipe shall be filled with water and all air shall be expelled. During the test, water shall be added, as needed, to maintain the test pressure. The amount of water added shall be recorded so as to calculate leakage. Leakage shall not exceed 25 gallons per day per mile per inch nominal pipe diameter. During the test, the owner and the Wastewater Treatment Plant Operator shall walk the route of the force main and examine the exposed pipe and the ground covering any backfilled pipe to discover leaks. Leakage in excess of that specified above shall be corrected with new material at the owner's expense and the test repeated. Any observed leaks shall be repaired at the owner's expense. Each test section length shall be as approved by the Wastewater Treatment Plant Operator, but in no event longer than one thousand (1,000) feet.

Section 407 - Final Acceptance and Warranty/Surety

All sanitary sewers and extensions to sanitary sewers constructed at the applicant's expense, after final approval and acceptance by the Wastewater Treatment Plant Operator, and concurrence by the Town of Hague Board, shall become the property of the Town of Hague, and shall thereafter be operated and maintained by the Town of Hague. No sanitary sewer shall be accepted by the Town of Hague until four (4) copies of as-built drawings have been so filed with the Wastewater Treatment Plant Operator and the Wastewater Treatment Plant Operator has approved the submitted drawings. Said sewers, after their acceptance by the

Town of Hague, shall be guaranteed against defects in materials or workmanship for one (1) year, by the applicant. The guarantee shall be in such form and contain such provision as deemed necessary by the Town of Hague Board, secured by a surety bond or such other security as the Town of Hague Board may approve.

Section 408 - Liability Insurance Coverage During Construction Period

(1) All contractors engaged in connecting house laterals with sanitary sewers, who perform any work within the Right of Way of any highway, shall file a bond in the amount of Five Thousand Dollars (\$5,000.00) with the Town of Hague Clerk to indemnify the Town of Hague against loss, cost, damage or expense sustained or recovered on account of any negligence, omission or act of the applicant for such a permit, or any of his, or their agents arising or resulting directly or indirectly by reason of such permit or consent, or of any act, construction or excavation done, made or permitted under authority of such permit or consent. All bonds shall contain a clause that permits given by the Town of Hague (Board) may be revoked at any time for just cause.

2) Before commencing work, the above contractor shall file insurance certificates with the Town of Hague Clerk for the following:

(a) Worker's Compensation and Employer's Liability Insurance as required by the laws of the State covering the contractor;

(b) Personal Injury Liability having limits of not less than \$500,000 each occurrence and \$500,000 aggregate (completed operations/products, personal injury);

(c) Property Damage Liability having limits of not less than \$500,000 for all damages arising during the life of the contract; and shall include, but not be limited to, the following designated hazards:

- i - Premises and Operations;
- ii - Independent Contractors;
- iii - Completed operations and products;
- iv - Property Damage; and
- v - Explosions, collapse and underground;

(d) Comprehensive automobile liability (including non-owned and hired automobiles) having limits of not less than:

- i - Bodily injury - each person, \$300,000
each occurrence, \$500,000
- ii - Property damage - each occurrence, \$500,000

(e) Business Excess Liability Insurance in the amount of \$2,000,000.

(f) All insurance policies must provide for five (5) business days notice to the Town of Hague before cancellation and must cover all liabilities of the Town of Hague and be in a form approved by the Town of Hague Board and be in a satisfactory form approved by the Board.

(g) The minimum insurance limits stated above shall be subject to periodic review by the Town of Hague Board and adjustments made, by resolution, as appropriate.

(3) Where it is necessary to enter upon or excavate any highway or cut any pavement, sidewalk or curbing, permission must be obtained from the Superintendent of Highways if a Town of Hague Highway is involved, from the County Department of Public Works if a County Highway is involved, and/or the New York State Department of Transportation if a State Highway is involved.

(4) The minimum insurance limits above shall be as established by the Town of Hague Board and shall be subject to periodic review and adjustment, as appropriate, by the Town of Hague Board.

Article 5

Building Laterals, Street Laterals Connections, and Fees

Section 501A - Permit Required for Sewer Connections

Section 501B - Inflow/Infiltration Prohibited

Section 502 - Sewer Lateral Permits

Section 503A - New Building Laterals

Section 503B - Laterals Serving Several Buildings

Section 503C - Laterals Serving Complexes

Section 503D - Dry Sewers

Section 504 - Using Existing Building Laterals

Section 505 - Lateral Pipe Materials

Section 506A - Street Lateral to Public Sewer Connection

Section 506B - Future Connection Locations; As-Built Drawings

Section 506C - Special Manhole Requirements

Section 507 - Laterals At and Near Buildings

Section 508 - Sewage Lifting

Section 509 - Lateral Pipe Installation

Section 510A - Watertight Joints

Section 510B - Cast Iron Pipe Poured Joints

Section 510C - Cast Iron Push Joints

Section 510D - PVC Push Joints

Section 510E - HDPE Fusion Joints

Section 511A - Building Lateral/Street Lateral Connection

Section 511B - Cleanout Repair/Replacement
Section 511C - Street Lateral Replacement; Ownership
Section 512 - Testing
Section 513A - Connection Inspection
Section 513B - Trench Inspections
Section 514 - Public Safety Provisions Required; Restoration of Disturbed Areas
Section 515 - Interior Clean-Out
Section 516 - Costs Borne by Owner

Section 501 A - Permit Required for Sewer Connections

No unauthorized person shall uncover, make any connection with or opening into, use, alter, or disturb any public sewer or appurtenance thereof without first obtaining a written permit from the Wastewater Treatment Plant Operator.

Section 501 B - Inflow/Infiltration Prohibited

No person shall discharge or cause to be discharged any storm cooling water or unpolluted industrial waters to any sanitary sewer. Swimming pool drains shall not be connected to any sanitary sewer.

Section 502 - Sewer Lateral Permits

There shall be two classes of sewer lateral permits:

- (1) For residential, commercial, and institutional service,
- (2) For service to establishments producing industrial wastes.

In either case, a permit application shall be submitted to the Zoning Enforcement Officer. The permit application shall be supplemented by any plans, specifications, or other information considered pertinent, in the judgment of the Wastewater treatment Plant Operator. A fee, for residential, commercial, institutional and industrial users, as established by the Town of Hague Board, shall accompany the application.

Connections to existing manholes shall be made as directed by the Wastewater Treatment Plant Operator.

Section 602B – Expiration of Permits

Any permit issued pursuant to this Law shall expire within 60 days from the date of issuance thereof, unless within such 60-day period such permit and plans shall have been filed and duly recorded by the Applicant in the Town Clerk's Office.

Unless otherwise provided for in the permit, all permits shall expire within 2 years of the date of issuance. Once a permit expires and the wastewater disposal system work is not completed, a new permit application is required.

Section 503 A - New Building Laterals

A separate and independent building lateral shall be provided for every building requiring sanitary facilities. When, however, there is a building behind a front building, the second building may use the front building's building lateral, if there is no other way to provide sanitary service to the back building.

New street laterals and/or building laterals shall not go under building basements. In like fashion, a building shall not be constructed over an existing lateral; the lateral shall be relocated after the Wastewater Treatment plant Operator has approved plans showing the relocation. If relocation is not physically possible then the lateral shall be:

- (1) exposed and totally encapsulated in not less than three inches of concrete, or
- (2) exposed and walled and the building rooms above positively ventilated outdoors.

All existing manholes in or under the basement shall be sealed airtight in a manner acceptable to the Wastewater Treatment Plant Operator. No new manholes shall be constructed on the portion of the lateral under the building.

Section 503 B -Laterals Serving Several Buildings

When building laterals are to serve multiple dwelling structures, the building lateral shall be sized in accordance with the metered water use and with sound professional engineering judgment.

Section 503 C - Laterals Serving Complexes

Where a lateral sewer is to serve a complex of industrial, commercial, institutional, or dwelling structures, special design of the building lateral system shall be required. Such lateral sewer shall be connected to the public sewer through a manhole. The Wastewater Treatment Plant Operator shall determine if and where this connection to the public sewer is required. If required, a new manhole shall be installed in the public sewer pursuant to Section 503 D and 1007 and the lateral connection made and tested as directed by the Wastewater Treatment Plant Operator. Plans and specifications shall be prepared and submitted for approval pursuant to this Law.

Section 503 D - Dry Sewers

Dry Sewers shall be designed and installed in accordance to this Law.

Section 5604 - Using Existing Building Laterals

Existing building laterals may be used in connection with new buildings only when they are found, on examination by the Wastewater Treatment Plant Operator, to meet all

requirements of this local Law.

Section 505 - Lateral Pipe Materials

Building and street lateral pipe materials shall be one of the following:

1) Tar-coated, service grade, cast iron soil pipe conforming to ASTM Specification A-74, "Cast Iron Pipe and Fittings". All dimensions, weight and markings of the pipe shall conform to the requirements of ANSI, Designation A112.5.1, except spigot ends shall be "plain end", if gasket joints are used.

(2) Polyvinyl chloride (PVC) pipe and fittings conforming to ASTM Specification D-3034-73, "SDR-35 Polyvinyl Chloride (PVC) Sewer Pipe and Fittings". All pipe shall be suitable for gravity sewer service. Provisions shall be made for contraction and expansion at each joint with a rubber ring. The bell shall consist of an integral wall section stiffened with two PVC retainer rings which securely lock the solid cross-section ring into position. Minimum "Pipe Stiffness" (F/Y) at five percent (5%) deflection shall be 46 PSI when tested in accordance with ASTM Specification D-2412.

(3) Polyvinyl chloride (PVC) pressure sewer pipe and fittings conforming to ASTM specification D2241, with rubber-gasketed integral bell push-on joints in conformance with ASTM Specification D3139. Minimum pressure class shall be SDR 21. All pipe shall be suitable for pressure sewer service.

(4) High Density Polyethylene (HDPE) Sewer Pipe and Fittings conforming to ASTM Specification F714. All pipe shall be suitable for pressure sewer service. Joints shall be butt fusion welded in accordance with the manufacturers' requirements or reinforced compression type with an internal stainless steel stiffener. Minimum wall thickness shall be SDR 7. HDPE Sewer Pipe shall be used only for low-pressure sewer laterals.

Any part of the building or street gravity sewer lateral that is located within five (5) feet of a water main or water service shall be constructed of cast iron soil pipe or pressure-rated PVC pipe. Cast iron soil pipe may be required by the Wastewater Treatment Plant Operator where the building or street lateral is likely to be damaged by tree roots. If installed on fill or unstable ground, the building or street lateral shall be of cast iron soil pipe, although other pipe material may be permitted if such pipe is uniformly supported on a poured concrete cradle approved by the Wastewater Treatment Plant Operator. The distance between consecutive joints, as measured along the centerline of the installed pipe, shall not be less than ten (10) feet, except under abnormal circumstances, in which case this dimension may be diminished, if approved by the Wastewater Treatment Plant Operator. The size and slope of building and street laterals shall be subject to approval by the Wastewater Treatment Plant Operator, but in no event shall the internal pipe diameter be less than 4 inches, nor shall the pipe slope for gravity sewer laterals be less than 1/4 inch per foot.

The street lateral for low-pressure sewers shall include a full port curb stop with flow-through diameter equal to that of the lateral. A curb box shall be installed. A redundant, full port check valve designed specifically for low-pressure sewer service shall be provided

before the curb stop for all low-pressure sewer laterals.

Section 506 A - Street Lateral to Public Sewer Connection

At the point of connection of a gravity sewer street lateral to a main sewer, a standard wye fitting and sufficient one-eighth (45 degree) bend fittings shall be used. The wye fittings shall be installed so that flow in the "arm" shall transition smoothly into the flow in the public sewer. No lateral connection shall be made to the public sewer which permits the flow into the public sewer from the lateral to enter at right angles.

The inside diameter of the fittings shall be same diameter as the street lateral inside diameter.

At the point of connection of a low-pressure sewer lateral to a main sewer, a stainless steel tapping saddle designed specifically for use with the material and pressure class of the low-pressure sewer main shall be installed for all connections to existing sewers. A sidewall-fusion tee fitting, or an in-line fusion welded HDPE tee shall be used for all low-pressure sewer laterals where new sewer mains are constructed.

Section 506 B - Future Connection Locations; As-Built Drawings

The gravity sewer street lateral, including the wye and eighth bend fittings, shall be connected to the main sewer at the time of constructing the main sewer, for each proposed lot for either immediate or future development. Laterals installed for future development shall be fitted a standard plug approved for use by the Wastewater Treatment Plant Operator. All sewer connections shall be via an in-line sanitary wye fitting or properly installed corrosion resistant saddle on the main sewer pipe. No portion of the lateral pipe shall protrude into the main sewer pipe. The location of all lateral connections shall be field marked with a 2 inch by 6-inch corrosion and rot resistant board. The marker board shall extend from the depth of the lateral to a minimum of two (2) feet above grade. The location of all lateral connections shall be indicated on a drawing with a minimum of three (3) tie lines indicated. Four (4) copies of this drawing, showing the as-built location of these connections, shall be furnished to the Wastewater Treatment Plant Operator. A refundable deposit shall be placed with Town of Hague to assure receipt of these as-builts. The deposit shall be placed when application is made; the amount of the deposit shall be \$100 per sheet of plans showing locations of lateral connections. No sanitary sewer shall be accepted by Town of Hague until four (4) copies of this record drawing have been so filed with the Wastewater Treatment Plant Operator and the Wastewater Treatment Plant Operator has approved the submitted drawings.

Section 506 C - Special Manhole Requirements

When any street lateral is to serve a school, hospital, or similar institution, or public housing, or is to serve a complex of industrial or commercial buildings, or which, in the opinion of the Zoning Enforcement Officer, will receive wastewater or industrial wastes of such volume or character that frequent maintenance of said building or street lateral is

anticipated, then such street lateral shall be connected to the public sewer through a manhole. The Wastewater Treatment Plant Operator shall determine if and where this type of connection to the public sewer is required. Connections to existing manholes shall be made as directed by the Wastewater Treatment Plant Operator. If required, a new manhole shall be installed in the public sewer pursuant to Sections 504 and 1007, and the lateral connection made thereto as directed by the Wastewater Treatment Plant Operator.

Section 507 - Laterals At and Near Buildings

Building laterals laid parallel to a bearing wall shall not be installed closer than three (3) feet to such wall. The building lateral shall enter the basement through the basement wall no less than twelve (12) inches above the basement floor. In no event shall any building lateral be placed below the basement floor, except with the expressed written approval of the Zoning Enforcement Officer.

The building lateral shall be laid at uniform grade and in straight alignment insofar as possible. Changes in direction shall be made only with properly curved pipe and fittings. Changes of direction of 90 degrees or greater shall be made with a cleanout which extends to grade, terminating in a terminal box set in concrete. In building laterals, said cleanouts shall be provided such that the maximum distance between cleanouts is 75 feet. The ends of all building or street laterals, which are not connected to the interior plumbing of the building, for any reason, shall be sealed against infiltration by a suitable stopper, plug, or by other approved means.

Section 508 - Sewage Lifting

In all buildings in which any building drain is too low to permit gravity flow to the public sewer, wastewater carried by such drain shall be lifted by mechanical means and discharged to the building lateral, on approval of the Wastewater Treatment Plant Operator.

Section 509 - Lateral Pipe Installation

All excavations required for the installation of a building or street lateral shall be open trench work unless otherwise approved by the Wastewater Treatment Plant Operator. Pipe laying and backfilling, regardless of pipe material used, shall be performed in general accordance with paragraphs 3 through 6 of ASTM Specification C-12, except that trench width, measured at the top of the installed pipe, shall not exceed the outside pipe diameter plus 14 inches and, except that no backfill shall be placed until the work has been inspected. The depth of cover over the pipe shall be sufficient to afford protection from frost, but no in any case shall such depth be less than four and one-half (4 1/2) feet. Where it is physically impossible to provide cover of four and one half (4 1/2) feet, the depth may be reduced to a minimum of two (2) feet and the pipe shall be insulated, as approved by the Wastewater Treatment Plant Operator.

Section 510 A - Watertight Joints

All joints and connections shall be made watertight.

Section 510 B - Reserved for Future Use

Section 510 C - Cast Iron Push Joints

Pre-molded gaskets may be used for hub and plain end cast iron pipe joints and joints with fittings, if approved by the Wastewater Treatment Plant Operator. The gasket shall be a neoprene compression-type unit which provides a positive seal in the assembled joint. The gasket shall be pre-molded, one-piece unit, designed for joining the cast iron hub and plain end soil pipe and fittings. The assembled joint shall be sealed by compression of the gasket between the exterior surface of the spigot and the interior surface of the hub. The joint shall be assembled following the manufacturer's recommendations using acceptable lubricant and special pipe-coupling tools designed for that purpose. The plain spigot end shall be forced into the hub end of the pipe for the full depth of the hub itself. Lubricant shall be a bland, flax-base, non-toxic material, and shall not chemically attack the gasket material.

Section 510 D - PVC Push Joints

Joints for PVC sewer pipe shall follow the manufacturer's recommendations, using properly designed couplings and rubber gaskets pursuant to the published information relating thereto, and conforming to the applicable ASTM specification identified in Section 605.

Section 511 A - Building Lateral/Street Lateral Connection

(1) The connection of the building lateral to an existing street lateral shall be made at the property line. Except as provided under Section 502, if a street lateral has not previously been provided, the street lateral will be constructed from the existing public sewer to the property line, by a licensed plumber, at the owner's expense. The street lateral shall be installed with a properly sealed and covered clean-out to grade located at the property line. The clean-out shall terminate at grade with a cast iron threaded ferrule and a 4 inch male threaded bronze plug with a 1-1/2 inch square raised nut.

(2) The cost of constructing the street lateral from the existing public sewer to the property line shall be at the property owner's expense; all subsequent costs and expense incidental to the installation and connection of the building lateral shall also be borne by the owner.

(3) The property owner shall indemnify the Town of Hague from any loss or damage that may directly or indirectly be occasioned by the installation of the building lateral.

4) It shall be the responsibility of the property owner to maintain, repair, or replace the building lateral, as needed.

(5) The method of connection of the building lateral to the street lateral will be dependent upon the type of sewer pipe material, and, in all cases, shall be approved by the Wastewater Treatment Plant Operator. After installation of the street lateral has been approved by the

Wastewater Treatment Plant Operator, the new street lateral shall become the property of the Town of Hague. Any subsequent repairs to the new street laterals shall be made by the Town of Hague at the Town of Hague's expense.

Section 511 B - Cleanout Repair/Replacement

If, in the judgment of the Wastewater Treatment Plant Operator, it is determined that a building lateral, without a property line clean-out, needs repair or replacement, the Town of Hague may install a clean-out at the property line, at the property owner's expense, such that the street lateral can be maintained independently of the building lateral.

Section 511 C - Street Lateral Replacement; Ownership

Any existing street lateral which, upon examination by the Wastewater Treatment Plant Operator, is determined to be in need of replacement will be replaced with a new street lateral with a property line clean-out. The replacement street lateral shall be constructed by a licensed plumber. The cost of constructing the replacement street lateral and clean-out shall be at the property owner's expense. Once the replacement street lateral and clean-out have been constructed and approved by the Wastewater Treatment Plant Operator, the new street lateral shall become the property of the Town of Hague. Any repairs to new street laterals shall be made by the Town of Hague at the Town of Hague's expense.

Section 512 - Testing

The street lateral, building lateral, or the combined lateral shall be tested for infiltration/exfiltration by:

- (a) any full pipe method described in Section 505, or
- (b) by a suitable joint method, with the prior written approval of the Wastewater Treatment Plant Operator.

Section 513 A - Connection Inspection

The applicant for the building lateral permit shall notify the Wastewater Treatment Plant Operator when the building lateral is ready for inspection and connection is to be made to the street lateral. The connection shall be made under the supervision of the Wastewater Treatment Plant Operator.

The applicant for the street lateral permit shall notify the Wastewater Treatment Plant Operator when the street lateral is ready for inspection and connection is to be made to the main sewer. The connection shall be made under the supervision of the Wastewater Treatment Plant Operator.

Section 513 B - Trench Inspections

When trenches are excavated for the laying of building lateral pipes or for laying of street lateral pipes, such trenches shall be inspected by the Wastewater Treatment Plant Operator. Before the trenches are backfilled, the person performing such work shall notify the Wastewater Treatment Plant Operator when the laying of the building lateral is completed, and no backfilling of trenches shall begin until approval is obtained from the Wastewater Treatment Plant Officer.

Section 514 - Public Safety Provisions Required; Restoration of Disturbed Areas

All excavations for constructing building laterals shall be adequately protected with barricades and lights so as to protect the public from hazard. Streets, sidewalks, parkways, and other public property disturbed, in the course of the work, shall be restored in a manner satisfactory to the Wastewater Treatment Plant Operator. When installation requires disturbance of paved public roads and shoulders, restoration shall involve backfilling to road grade. Shortly thereafter the Town of Hague Highway Department shall complete road and shoulder restoration to the Town of Hague Standards. The cost for such final road and shoulder restoration by the DPW shall be included with the fees paid with the application for the permit required in Section 602.

Section 515 - Interior Clean-Out

An interior clean-out fitting shall be provided for each building lateral at a readily accessible location, preferably just inside the basement wall. The fitting shall contain a 45-degree branch with removable plug or test tee, and so positioned that sewer cleaning and inspection equipment can be inserted therein to clean or inspect the building lateral.

The cleanout diameter shall be no less than the building lateral diameter.

Section 516 - Costs Borne by Owner

All costs associated with the provisions of this Article shall be borne by the property owner unless specifically stated or agreed to be a cost borne by the Town of Hague. The property owner shall indemnify the Town of Hague from any loss or damage that may be directly or indirectly occasioned by the installation of the building and street laterals, and connections and appurtenances.

Article 6

Inflow

Section 601 - New Inflow Sources Prohibited

Section 602 - Existing Inflow Sources Disconnected

Section 603 - Existing Inflow Sources Disconnected When Property Sold

Section 604 - No Re-connection of Inflow Source Allowed

Section 605 - Charges for Inflow

Section 601 - New Inflow Sources Prohibited

No connections shall be made to a sanitary or to a combined sewer which connections are intended to discharge inflow. Such prohibited connections include, but are not limited to, footing drains, roof leaders, roof drains, cellar drains, sump pumps, catch basins, uncontaminated cooling water discharges, or other sources of inflow.

Section 602 - Existing Inflow Sources Disconnected

For properties where separate storm sewers are available within 100 feet of the property line or where, in the judgment of the Wastewater Treatment Plant Operator, sufficient natural drainage is available, connections which contribute inflow to the sanitary sewers must be disconnected in a fashion approved by the Wastewater Treatment Plant Operator, prior to the sale of the property.

Section 603 - Existing Inflow Sources Disconnected When Property Sold

Upon notice from the Tax Assessor, the Wastewater Treatment Plant Operator shall inspect any newly sold property for the purpose of determining if storm sewers or natural drainage is available, and, if so, if all connections which contribute inflow have been disconnected.

Section 604 - No Re-connection of Inflow Source Allowed

It shall be a willful violation of this Law for any person to reconnect any inflow source which has been disconnected pursuant to this Article.

Section 605 - Charges for Inflow

The Wastewater Treatment Plant Operator is enabled to take whatever action is necessary to determine the amount of inflow including the requirement for installation of a control manhole. The property from which the inflow originated shall be billed for inflow according to Article 12, however, the Town of Hague Board may cause a surcharge at a rate not to exceed five (5) times that for normal sewage volume charge.

ARTICLE 7

Trucked Or Hauled Waste

- Section 701 - Licenses and Application
- Section 702 - Concurrent Requirements
- Section 703 - Dumping Location and Timing
- Section 704 - Notification of Dumping

Section 701 - Licenses and Application

The discharge of trucked or hauled wastes into the Town of Hague sewer system and public sewers tributary thereto will be permitted only with the written approval (license) of the Town Board and Wastewater Treatment Plant Operator. Applicants for such license shall apply on a form provided by the Wastewater Treatment Plant Operator. These forms may require information such as vehicle specifications, vehicle license number, vehicle color, NYSDEC permits issued under 6 NYCRR Part 364, approximate annual septage volume expected, service area, and any other information that the Superintendent may require, to determine whether the trucked or hauled wastes could adversely impact the POTW. The application shall be accompanied by a fee prescribed by the Town Board not to exceed \$100.

The licensee of trucked or hauled wastes will also be charged a fee for each dumping, in accordance with Article 12. The dumping fee shall be paid prior to dumping.

Section 702 - Concurrent Requirements

The applicant for a license to truck or haul wastes shall be the owner of the vehicle or vehicles to be used for such discharge. Any false or misleading statement, in any license application, shall be grounds for invalidating the license. All licenses, issued by the Wastewater Treatment Plant Operator, for this purpose, shall be for one (1) year. The licensee shall also be duly permitted by the NYSDEC under 6 NYCRR Part 364 ("364 permit"). If, for any reason, the 364 permit is revoked, the 364 permit lapses or becomes invalid, then the license issued under this Article shall become invalid immediately. All acts performed in connection with the license shall be subject to the inspection and regulations, as established by the Wastewater Treatment Plant Operator, the terms and conditions of the license and all local and general laws, ordinances, and regulations which are now or may come into effect, and such license may be suspended or revoked, at any time, by the Wastewater Treatment Plant Operator for willful, continued, or persistent violation thereof.

Section 703 - Dumping Location and Timing

The Wastewater Treatment Plant Operator may require discharging at only certain locations within the POTW, and only at certain times, and on only certain days of the week, or seasons of the year as shall be stated on said license or as may be relocated by the Wastewater Treatment Plant Operator, after appropriate notice. The time and conditions for permissible discharge shall be as set forth on the license, or as may be revised by the Wastewater Treatment Plant Operator, after appropriate notice.

Section 704 - Notification of Dumping

Each discharge of trucked or hauled wastes shall be made only with the approval of the Superintendent. The Superintendent may require inspection, sampling, and analysis of each load prior to the discharge of a load. Any extra costs associated with such inspection, sampling, and analysis shall be paid by the licensee.

Article 8

Discharge Restrictions

Section 801 - Pretreatment Standards
Section 802 - General Prohibitions
Section 803 - Concentration Based Limitations
Section 804 - Mass Discharge Based Limitations
Section 805 - Modification of Limitations
Section 806 - Access to User's Records
Section 807 - Dilution
Section 808 - Grease, Oil, and Sand Interceptors
Section 809 - Solid Waste Grinders
Section 810 - Rejection of Wastewater

Section 801 - Pretreatment Standards

All users of the Town of Hague POTW will comply with all standards and requirements of the Act and standards and requirements promulgated pursuant to the Act, including but not limited to 40 CFR Parts 406 - 471.

Section 802 - General Prohibitions

No user shall contribute or cause to be contributed, in any manner or fashion, directly or indirectly, any pollutant or wastewater which will interfere with the operation or performance of the POTW. These general prohibitions apply to all such users of a POTW whether or not the user is subject to National Categorical Pretreatment Standards, or any other National, State, or Local Pretreatment Standards or Requirements.

Without limiting the generality of the foregoing, a user may not contribute the following substances to the POTW:

(1) Any solids, liquids, or gases which, by reason of their nature or quantity, are or may be sufficient, either alone or by interaction with other substances, to cause a fire or an explosion or be injurious, in any way, to the POTW, or to the operation of the POTW. At no time shall both of two successive readings on a flame type explosion hazard meter, at the point of discharge into the system (or at any other point in the system) be more than 25 % nor any single reading be more than 40 % of the lower explosive limit (LEL) of the meter. Unless explicitly allowable by a written permit, prohibited materials include, but are not limited to, gasoline, kerosene, naphtha, benzene, toluene, xylene, ethers, alcohols, carbides, hydrides, and sulfides, and any other substance which the Town of Hague, the State, or the EPA has determined to be a fire hazard, or hazard to the POTW.

2) Solid or viscous substances which may cause obstruction to the flow in a sewer or otherwise interfere with the operation of the wastewater treatment facilities. Unless explicitly allowable by a written permit, such substances include, but are not limited to, grease, garbage with particles greater than one-half (1/2) inch in any dimension, animal guts or tissues, paunch manure, bones, hair, hides or fleshings, entrails, whole blood, feathers, ashes, cinders, sand, spent lime, stone or marble dust, metal, glass, straw, shavings, grass

clippings, rags, spent grains, spent hops, waste paper, wood, plastics, gas, tar asphalt residues, residues from refining or processing fuel or lubricating oil, mud, or glass or stone grinding or polishing wastes.

(3) Any wastewater having a pH less than 5.0 or greater than 10.0, unless the POTW was specifically designed to manage such wastewater, or wastewater having any other corrosive property capable of causing damage or hazard to structures, equipment, and/or POTW personnel.

(4) Any wastewater containing toxic pollutants in sufficient quantity, either singly or by interaction with other pollutants (including heat), to injure or interfere with any wastewater treatment process, constitute a hazard to humans or animals, create a toxic effect in the receiving waters of the POTW, or to exceed the limitation set forth in a Categorical Pretreatment Standard.

A toxic pollutant shall include, but not be limited to, any pollutant identified pursuant to Section 307(A) of the Act.

(5) Any noxious or malodorous solids, liquids, or gases which either singly or by interaction with other wastes are sufficient to create a public nuisance or a hazard to life or are sufficient to prevent entry into the sewers for their maintenance or repair.

6) Oils and grease - Any commercial, institutional, or industrial wastes containing fats, waxes, grease, or oils which become visible solids when the wastes are cooled to 10 degrees centigrade (50 degrees Fahrenheit); any petroleum oil, non-biodegradable cutting oil, or products of mineral oil origin, in excess of 100 mg/l or in amounts that will cause interference or pass through.

7) Any wastewater which will cause interference or pass through.

(8) Any wastewater with objectionable color which is not removed in the treatment process, such as, but not limited to, dye wastes, and vegetable tanning solutions.

(9) Any solid, liquid, vapor, or gas having a temperature higher than 65 degrees C (150 degrees F); however, such materials shall not cause the POTW treatment plant influent temperature to be greater than 40 degrees C (104 degrees F). The Wastewater Treatment Plant Operator reserves the right, in certain instances, to prohibit or limit the discharge of wastes whose maximum temperatures are lower than 65 degrees C.

(10) Unusual flow rate or concentration of wastes, constituting slugs, except by Industrial Wastewater Permit.

(11) Any wastewater containing any radioactive wastes except as approved by the Wastewater Treatment Plant Operator, and in compliance with applicable State and Federal regulations.

(12) Any wastewater which causes a hazard to human life or which creates a public nuisance, either by itself or in combination, in any way, with other wastes.

(13) Any wastewater with a closed cup flashpoint of less than 140 degrees Fahrenheit or 60 degrees Centigrade using the test methods specified in 40 CFR Part 261.21.

(14) Any pollutants which result in the presence of toxic gases, vapors or fumes within the POTW in a quantity that may cause acute worker health and safety problems.

Section 803 - Concentration Based Limitations

No person shall discharge, directly or indirectly, into the POTW, wastewater containing any of the following substances in concentrations exceeding those specified below on either a daily or an instantaneous basis, except by permit or as provided for in Section 904. Concentration limits are applicable to wastewater effluents at the point just prior to discharge into the POTW ("end of pipe" concentrations).

Effluent Concentration Limit - mg/l

<p align="center">Substance (1)</p>	<p align="center">Allowable Average Daily (2)</p>	<p align="center">Allowable Maximum Instantaneous (3)</p>
<p>Aluminum Antimony Arsenic Barium Beryllium Bismuth Bromine Cadmium Chlorides Chlorine Chromium (hex) Chromium (tot) Cobalt Copper Cyanide (complex) Cyanide (free) Fluorides Gold Iodine Iron</p>		

Lead Manganese Mercury Molybdenum Nickel Phenols, total Selenium Silver Sulfates Sulfides Tin Titanium Vanadium Zinc		
---	--	--

(1) Except for chromium (hex), all concentrations listed for metallic substances shall be as "total metal", which shall be defined as the value measured in a sample acidified to a pH value of 2 or less, without prior filtration.

(2) As determined on a composite sample taken from the User's daily discharge over a typical operational and/or production day.

(3) As determined on a grab sample taken from the User's discharge at any time during the daily operational and/or production period.

(4) Other substances which may be limited are:

- alkanes, alkenes and alkynes
- aliphatic and aromatic alcohols and acids
- aliphatic and aromatic aldehydes and ketones
- aliphatic and aromatic esters
- aliphatic and aromatic halogenated compounds
- aliphatic and aromatic nitro, cyano and amino compounds
- antibiotics
- benzene derivatives
- chemical compounds which, upon acidification, alkalization, oxidation or reduction, in the discharge or after admixture with wastewater and its components in the POTW, produce toxic, flammable, or explosive compounds
- pesticides, including algicides, fungicides, herbicides, insecticides, rodenticides
- phthalates
- polyaromatic and polynuclear hydrocarbons
- total toxic organics, TTO, as defined in 40 CFR 433.11
- toxic organic compounds regulated by Federal Pretreatment Standards
- unsaturated aliphatics, including those with an aldehyde, ketone or nitrile functional group
- viable pathogenic organisms from industrial processes or hospital procedures

Section 804 - Mass Discharge Based Limitations

At no time shall the influent to the POTW contain quantities in excess of those specified below:

Allowable POTW Influent Loading

Substance	Average Daily (pounds per day)
Aluminum	
Antimony	
Arsenic	
Barium	
Beryllium	
Bismuth	
Bromine	
Cadmium	
Chromium (hex)	
Chromium (tot)	
Cobalt	
Copper	
Cyanide (complex)	
Cyanide (free)	
Fluorides	
Gold	
Iron	
Lead	
Manganese	
Mercury	
Nickel	
Phenols, (total)	
Selenium	
Silver	
Sulfide	
Tin	
Titanium	
Vanadium	
Zinc	

The Wastewater Treatment Plant Operator shall determine the total allowable influent load of each substance from significant industrial users. In determining the total load of each substance that significant industrial users shall be allowed to discharge, the Wastewater

Treatment Plant Operator shall consider:

- (1) the quantities of each substance that are uncontrollable because they occur naturally in wastewater,
- (2) the quantities of each substance that are anthropogenic but are nonetheless uncontrollable,
- (3) historical discharge trends,
- (4) past pollution control efforts of each significant industrial user as compared to other significant industrial dischargers of the same substance,
- (5) potential for growth in the POTW service area, (6) potential for more restrictive regulatory requirements to be placed on the POTW discharge or sludge disposal or sludge reuse method, and
- (7) treatability of the substance. The Wastewater Treatment Plant Operator shall apply a minimum 15 % safety factor to be protective of the POTW.

To assure that the total loads so calculated, for each substance, are not violated, the Wastewater Treatment Plant Operator shall issue permits to significant industrial users limiting discharge loads.

Permits issued in accordance with this section may allow for discharges in excess of limitations set forth under section 903.

Section 805 - Modification of Limitations

Limitations on wastewater strength or mass discharge contained in this Law may be supplemented with more stringent limitations when, in the opinion of the Wastewater Treatment Plant Operator:

- (1) The limitations in this Law are not sufficient to protect the POTW,
- (2) The limitations in this Law are not sufficient to enable the POTW treatment plant to comply with applicable water quality standards or the effluent limitations specified in the POTW's SPDES permit,
- 3) The POTW sludge will be rendered unacceptable for disposal or reuse as the Town of Hague desires, as a result of discharge of wastewaters at the above prescribed concentration limitations,
- 4) Municipal employees or the public will be endangered, or
- (5) Air pollution and/or groundwater pollution will be caused.

The limitations on wastewater strength or mass discharge shall be recalculated not less frequently than once every five (5) years. The results of these calculations shall be reported to the Town of Hague Board. This Law shall then be amended appropriately. Any issued industrial wastewater discharge permits, which have limitations, based directly on any limitations, which were changed, shall be revised and amended, as appropriate.

Section 806 - Access to User's Records

The Wastewater Treatment Plant Operator shall have the authority to copy any record related

to wastewater discharges to the POTW.

Section 807 - Dilution

Except where expressly authorized to do so by an applicable Pretreatment Standard, no user shall ever increase the use of process water or, in any other way, attempt to dilute a discharge as a partial or complete substitute for adequate treatment to achieve compliance with a Pretreatment Standard.

Dilution flow shall be considered to be inflow.

Section 808 - Grease, Oil, and Sand Interceptors

Grease, oil, and sand interceptors shall be provided, when, in the opinion of the Wastewater Treatment Plant Operator, they are necessary for the proper handling of wastewater containing excessive amounts of grease, flammable substances, sand, or other harmful substances; except that such interceptors shall not be required for private living quarters or living units. All interceptors shall be of type and capacity approved by the Wastewater Treatment Plant Operator and shall be so located to be easily accessible for cleaning and inspection. Such interceptors shall be inspected, cleaned, and repaired regularly, as needed, by the owner, at his expense.

Grease interceptors shall be required for all establishments preparing or serving food.

Grease and oil interceptors shall be required for all automotive service and repair establishments.

Section 809 - Solid Waste Grinders

Solid waste grinders at or serving commercial establishments, institutions or industries shall not discharge into the Town of Hague POTW.

Residential solid waste grinders shall be subject to a surcharge in accordance with the Sewer Rate Schedule.

Section 810 - Rejection of Wastewater

The Town of Hague Board may reject a User's wastewater, on recommendation of the Wastewater Treatment Plant Operator, when it is has been determined that the wastewater contains substances or possesses characteristics which have a deleterious effect on the POTW and its processes, or on the receiving water, or which constitute a public nuisance or hazard. See Section 916.

Article 9

Discharge Permits And Pretreatment Requirements

Section 901 - Wastewater Discharge Reports

Section 902 - Notification to Industrial Users

Section 903 A - Wastewater Discharges

Section 903 B - Wastewater Discharge Permits Required For Significant Industrial Users
Section 903 C - Other Industrial Users
Section 903 D - Discharge Permits to Storm Sewers Not Authorized
Section 904 A - Application for Wastewater Discharge Permits
Section 904 B - Permit Modifications
Section 904 C - Permit Conditions
Section 904 D - Permit Duration
Section 904 E - Permit Reissuance
Section 904 F - Permit Transfer
Section 904 G - Permit Revocation
Section 904 H - Public Notification
Section 905 - Reporting Requirements for Permittee
Section 906 - Flow Equalization
Section 907 - Monitoring Stations (Control Manholes)
Section 908 - Proper Design and Maintenance of Facilities and Monitoring Stations
Section 909 - Vandalism, Tampering with Measuring Devices
Section 910 - Sampling and Analysis
Section 911 - Accidental Discharges; SPCC Plan
Section 912 - Posting Notices
Section 913 - Sample Splitting
Section 914 - Public Access to Information Maintained by the Town
Section 915 A - Access to Property and Records
Section 915 B - Access to Easements
Section 915 C - Liability of Property Owner
Section 916 - Special Agreements

Section 901 - Wastewater Discharge Reports

As a means of determining compliance with this Law, with applicable SPDES permit conditions, and with applicable State and Federal law, each industrial user shall be required to notify the Wastewater Treatment Plant Operator of any new or existing discharges to the POTW by submitting a completed Industrial Chemical Survey (ICS) form and a completed Industrial Wastewater Survey (IWS) form to the Zoning Enforcement Officer. The Wastewater Treatment Plant Operator may require any user discharging wastewater into the POTW to file wastewater discharge reports and to supplement such reports as the Wastewater Treatment Plant Operator deems necessary. All information shall be furnished by the user in complete cooperation with the Zoning Enforcement Officer.

Section 902 - Notification to Industrial Users

The Wastewater Treatment Plant Operator shall, from time to time, notify each industrial user of applicable Pretreatment Standards, and of other applicable requirements under Section 204(B) and Section 405 of the Clean Water Act, and Subtitles C and D of RCRA.

Section 903 A - Wastewater Discharges

No Significant Industrial User shall discharge wastewater to the POTW without having a valid Wastewater Discharge Permit, issued by the Wastewater Treatment Plant Operator. Significant Industrial Users shall comply fully with the terms and conditions of their permits in addition to the provisions of this Law. Violation of a permit term or condition is deemed a violation of this Law.

Section 903 B - Wastewater Discharge Permits Required For Significant Industrial Users

All Significant Industrial Users proposing to connect to or to discharge to the POTW shall obtain a Wastewater Discharge Permit before connecting to or discharging to the POTW. Existing significant industrial users shall make application for a Wastewater Discharge Permit within 30 days after the effective date of this Law, and shall obtain such a permit within 90 days after making application.

Section 903 C - Other Industrial Users

The Wastewater Treatment Plant Operator may issue Wastewater Discharge Permits to other industrial users of the POTW.

Section 903 D - Discharge Permits to Storm Sewers Not Authorized

The Town of Hague does not have the authority to issue permits for the discharge of any wastewater to a storm sewer. This authority rests with the NYSDEC.

Section 904 A - Application for Wastewater Discharge Permits

Industrial users required to obtain a Wastewater Discharge Permit shall complete and file with the Wastewater Treatment Plant Operator an application in the form prescribed by the Town of Hague, the application shall be accompanied by a fee, as set forth in Section 1203. In support of any application, the industrial user shall submit, in units and terms appropriate for evaluation, the following information:

- (1) Name, address, and location (if different from the address).
- (2) SIC code of both the industry and any categorical processes.
- (3) Wastewater constituents and characteristics including but not limited to those mentioned in Article 10 of this Law and which are limited in the appropriate Categorical Standard, as determined by a reliable analytical laboratory approved by the NYSDOH. Sampling and analysis shall be performed in accordance with Standard Methods.
- (4) Time and duration of the discharge.
- (5) Average daily peak wastewater flow rates, including daily, monthly, and seasonal variations, if any.
- (6) Site plans, floor plans, mechanical and plumbing plans, and details to show all sewers, sewer connections, and appurtenances.
- (7) Description of activities, facilities, and plant processes on the premises, including all materials which are or could be discharged to the POTW.

(8) Each product produced by type, amount, process or processes, and rate of production.

(9) Type and amount of raw materials processed (average and maximum per day).

(10) Number and type of employees, and hours of operation, and proposed or actual hours of operation of the pretreatment system.

(11) The nature and concentration of any pollutants in the discharge which are limited by any County, State, or Federal Standards, and a statement whether or not the standards are being met on a consistent basis and if not whether additional Operation and Maintenance (O&M) and/or additional pretreatment is required for the user to meet all applicable Standards.

(12) If additional pretreatment and/or O&M will be required to meet the Standards, then the industrial user shall provide the shortest schedule to accomplish such additional treatment and/or O&M. The completion date in this schedule shall not be longer than the compliance date established for the applicable Pretreatment Standard. The following conditions shall apply to this schedule:

(a) The schedule shall contain progress increments in the form of dates for the commencement and completion of major events leading to the construction and operation of additional pretreatment required for the user to meet the applicable Pretreatment Standards (such events include hiring an engineer, completing preliminary plans, completing final plans, executing contracts for major components, commencing construction, completing construction, beginning operation, and beginning routine operation).

(b) No increment referred to in (a) above shall exceed 9 months, nor shall the total compliance period exceed 18 months.

(c) No later than 14 calendar days following each date in the schedule and the final date for compliance, the user shall submit a progress report to the Wastewater Treatment Plant Operator including, as a minimum, whether or not it complied with the increment of progress to be met on such date and, if not, the date on which it expects to comply with this increment of progress, the reason for delay, and the steps being taken by the user to return to the established schedule. In no event shall more than 9 months elapse between such progress reports to the Wastewater Treatment Plant Operator.

(13) Any other information as may be deemed by the Wastewater Treatment Plant Operator to be necessary to evaluate the permit application.

The Wastewater Treatment Plant Operator will evaluate the data furnished by the industrial user and may require additional information. After evaluation and acceptance of the data furnished, the Town of Hague may issue a Wastewater Discharge Permit subject to terms and conditions provided herein.

Section 904 B - Permit Modifications

Wastewater Discharge Permits may be modified by the Wastewater Treatment Plant Operator, upon 30 days notice to the permittee, for just cause. Just cause shall include, but not be limited to:

(1) Promulgation of an applicable National Categorical Pretreatment Standard,

(2) Revision of or a grant of a variance from such categorical standards pursuant to 40 CFR

403.13,

- (3) Changes in general discharge prohibitions and local limits as per Section 903 of this law,
- (4) Changes in processes used by the permittee, or changes in discharge volume or character,
- (5) Changes in design or capability of any part of the POTW,
- (6) Discovery that the permitted discharge causes or contributes to pass through or interference, and
- (7) Changes in the nature and character of the sewage in the POTW as a result of other permitted discharges.

Any changes or new conditions in the permit shall include a reasonable time schedule for compliance as set forth in Section 1004 A (12)(a).

Section 904 C - Permit Conditions

Wastewater Discharge Permits shall be expressly subject to all the provisions of this Law, and all other applicable regulations, user charges and fees established by the Town of Hague. Permits may contain the following:

- (1) Limits on the average and maximum rate and time of discharge, or requirements for flow regulation and equalization.
- (2) Limits on the average and maximum wastewater constituents and characteristics, including concentration or mass discharge limits.
- (3) The unit charge or schedule of user charges and fees for the management of the wastewater discharged to the POTW.
- (4) Requirements for installation and maintenance (in safe condition) of inspection and sampling facilities.
- (5) Specifications for monitoring programs which may include sampling locations, frequency of sampling, number, types, and standards for tests, and reporting schedules.
- (6) Compliance schedules
- (7) Requirements for submission of technical reports or discharge reports.
- (8) Requirements for maintaining and retaining plant records relating to wastewater discharge, as specified by the Town of Hague, and affording the Wastewater Treatment Plant Operator access thereto.
- (9) Requirements for notification of the Town of Hague of any new introduction of wastewater constituents or of any substantial change in the volume or character of the wastewater constituents being introduced into the POTW.
- (10) Requirements for the notification of the Town of Hague of any change in the manufacturing and/or pretreatment process used by the permittee.
- (11) Requirements for notification of excessive, accidental, or slug discharges.
- (12) Other conditions as deemed appropriate by the Town of Hague to ensure compliance with this Law, and State and Federal laws, rules, and regulations.

Section 904 D - Permit Duration

Permits shall be issued for a specified time period, not to exceed five (5) years. A permit may be issued for a period less than five (5) years.

Section 904 E - Permit Reissuance

The user shall apply for permit reissuance a minimum of 180 days prior to the expiration of the user's existing permit. The terms and conditions of the permit may be subject to modification, by the Wastewater Treatment Plant Operator, during the term of the permit, as limitations or requirements, as identified in Section 904 B, or other just cause exists. The User shall be informed of any proposed changes in his permit at least 30 days prior to the effective date of the change. Any changes or new conditions in the reissued permit shall include a reasonable time schedule for compliance as established in Section 904 A (12)(a).

Section 904 F - Permit Transfer

Wastewater Discharge Permits are issued to a specific User for a specific operation, or discharge at a specific location. A Wastewater Discharge Permit shall not be reassigned, transferred, or sold to a new owner, new User, different premises, or a new or changed operation.

Section 904 G - Permit Revocation

Wastewater Discharge Permits may be revoked for the following reasons: falsifying self-monitoring reports, tampering with monitoring equipment, refusing to allow the Wastewater Treatment Plant Operator timely access to the industrial premises, failure to meet effluent limitations, failure to pay fines, failure to pay user charges, and failure to meet compliance schedules. Permit revocation process if necessary shall be initiated by the Wastewater Treatment Plant Operator. Zoning Enforcement Officer will issue revocation.

Section 904 H - Public Notification

The Town of Hague will publish in the Town of Hague official daily newspaper(s), informal notice of intent to issue a Wastewater Discharge Permit, at least 14 days prior to issuance.

Section 905 - Reporting Requirements for Permittee

The reports or documents required to be submitted or maintained under this section shall be subject to:

- (a) The provisions of 18 USC Section 901 relating to fraud and false statements;
- (b) The provisions of Sections 309(c)(4) of the Act, as amended, governing false statements, representation or certification; and
- (c) The provisions of Section (c)(6) of the Act, as amended, regarding corporate officers.

1) Baseline Monitoring Report

Within 180 days after promulgation of an applicable Federal Categorical Pretreatment Standard, a User subject to that standard shall submit, to the Wastewater Treatment Plant

Operator, the information required by paragraphs (8) and (9) of Section 904 A.

(2) 90-Day Compliance Report

Within 90 days following the date for final compliance with applicable Pretreatment Standards, or, in the case of a New Source, following commencement of the introduction of wastewater into the POTW, any User subject to Pretreatment Standards and Requirements shall submit, to the Wastewater Treatment Plant Operator a report indicating the nature and concentration of all pollutants in the discharge, from the regulated process, which are limited by Pretreatment Standards and Requirements, and the average and maximum daily flow for these process units in the User's facility which are limited by such Pretreatment Standards and Requirements. The report shall state whether the applicable Pretreatment Standards and Requirements are being met on a consistent basis, and, if not, what additional O&M and/or pretreatment is necessary to bring the User into compliance with the applicable Pretreatment Standards or Requirements. This statement shall be signed by an authorized representative of the Industrial User, and certified to by a qualified professional.

(3) Periodic Compliance Reports

a) Any User subject to a Pretreatment Standard, after the compliance date of such Pretreatment Standard, or, in the case of a New Source, after commencement of the discharge into the POTW, shall submit to the Wastewater Treatment Plant Operator, during the months of June and December, unless required more frequently in the Pretreatment Standard or by the Wastewater Treatment Plant Operator, a report indicating the nature and concentration of pollutants in the effluent which are limited by such Pretreatment Standards. In addition, this report shall include a record of all daily flows which, during the reporting period, exceeded the average daily flow reported in Section 1004 A. At the discretion of the Wastewater Treatment Plant Operator, and in consideration of such factors as local high or low flow rates, holidays, budget cycles, etc., the Wastewater Treatment Plant Operator may agree to alter the months during which the above reports are to be submitted, however, no fewer than two reports shall be submitted per year.

(b) The Wastewater Treatment Plant Operator may impose mass limitations on Users, which are using dilution to meet applicable Pretreatment Standards or Requirements, or, in other cases where the imposition of mass limitations are appropriate. In such cases, the report required by Section 905 (3) (a) shall indicate the mass of pollutants regulated by Pretreatment Standards in the effluent of the User. These reports shall contain the results of discharge sampling and analysis, including the flow, and the nature and concentration, or production and mass, where requested by the Wastewater Treatment Plant Operator, of pollutants contained therein, which are limited by the applicable Pretreatment Standard. All analyses shall be performed in accordance with Standard Methods, by a laboratory certified by NYSDOH to perform the

analyses.

(4) Violation Report

If sampling, performed by the user, indicates a violation of this Law and/or the User's discharge permit, the User shall notify the Wastewater Treatment Plant Operator within 24 hours of becoming aware of the violation. The User shall also repeat the sampling and analysis and submit the results of the repeat analysis to the Wastewater Treatment Plant Operator within 30 days after becoming aware of the violation. The User is not required to re-sample if the POTW performs monitoring of the User's discharge at least once a month for the parameter which was violated, or if the POTW performs sampling, for the parameter which was violated, between the User's initial sampling and when the User receives the results of this sampling.

(5) Other reports

The Wastewater Treatment Plant Operator may impose reporting requirements equivalent to the requirements imposed by Section 1005(3) for users not subject to pretreatment standards.

Section 906 - Flow Equalization

No person shall cause the discharge of slugs to the POTW. Each person discharging, into the POTW, greater than 100,000 gallons per day or greater than five percent (5%) of the average daily flow in the POTW, whichever is lesser, shall install and maintain, on his property and at his expense, a suitable storage and flow control facility to insure equalization of flow over a twenty-four (24) hour period. The facility shall have a capacity for at least fifty percent (50%) of the daily discharge volume and shall be equipped with alarms and a rate of discharge controller, the regulation of which shall be directed by the Wastewater Treatment Plant Operator. A wastewater discharge permit may be issued solely for flow equalization.

Section 907 - Monitoring Stations (Control Manholes)

(a) All Significant Industrial Users, and other Industrial Users whose industrial waste discharge has caused or may cause Interference or Pass-Through shall install and maintain a suitable monitoring station, on their premises at their expense, to facilitate the observation, sampling, and measurement of their industrial wastewater discharge.

(b) If there is more than one street lateral serving an Industrial User, the Wastewater Treatment Plant Officer may require the installation of a control manhole on each lateral.

(c) The Wastewater Treatment Plant Operator may require that such monitoring station(s) include equipment for the continuous measurement and recording of wastewater flow rate and for the sampling of the wastewater. Such station(s) shall be accessibly and safely located, and the Industrial User shall allow immediate access, without prior notice, to the

station by the Wastewater Treatment Plant Operator, or his designated representative.

Section 908 - Proper Design and Maintenance of Facilities and Monitoring Stations

Preliminary treatment, and flow equalization facilities, or monitoring stations, if provided for any wastewater, shall be constructed and maintained continuously clean, safe, and continuously operational by the owner at his expense. Where an Industrial User has such treatment, equalization, or monitoring facilities at the time this Law is enacted, the Wastewater Treatment Plant Operator may approve or disapprove the adequacy of such facilities. Where the Wastewater Treatment Plant Operator disapproves of such facilities and construction of new or upgraded facilities for treatment, equalization, or monitoring are required, plans and specifications for such facilities shall be prepared by a licensed professional engineer and submitted to the Wastewater Treatment Plant Operator. Construction of new or upgraded facilities shall not commence until written approval of the Wastewater Treatment Plant Operator has been obtained.

Section 909 - Vandalism, Tampering with Measuring Devices

No unauthorized person shall negligently break, damage, destroy, uncover, deface, tamper with, prevent access, or render inaccurate, or cause or permit the negligent breaking, damaging, destroying, uncovering, defacing, tampering with, preventing access, or rendering inaccurate to:

- i - any structure, appurtenance, or equipment which is a part of the Town of Hague POTW, or
- ii - any measuring, sampling, and/or testing device or mechanism installed pursuant to any requirement under this Law except as approved by the Zoning Enforcement Officer.

Section 910 - Sampling and Analysis

Sampling shall be performed so that a representative portion of the wastewater is obtained for analysis.

All measurements, tests, and analyses of the characteristics of waters and wastes required in any section of this Law shall be carried out in accordance with Standard Methods, by a laboratory certified by NYSDOH to perform the analyses. Such samples shall be taken at the approved monitoring stations described in Section 907, if such a station exists. If an approved monitoring station is not required, then samples shall be taken from another location on the industrial sewer lateral before discharge to the public sewer. Unless specifically requested otherwise, or unless specifically not allowed in Federal regulation, samples shall be gathered as flow proportioned (where feasible) composite samples made up of individual samples taken not less than once per hour for the period of time equal to the duration of industrial wastewater discharge during daily operations (including any cleanup shift).

Section 911 - Accidental Discharges; SPCC Plan

Each user shall provide for protection from accidental or slug discharges of prohibited materials or discharges of materials in volume or concentration exceeding limitations of this Law or of an Industrial Wastewater Discharge Permit. Users shall immediately notify the Wastewater Treatment Plant Operator of the discharge of wastes in violation of this Law or any Permit. Such discharges may result from:

- (1) Breakdown of pretreatment equipment
- (2) Accidents caused by mechanical failure, or negligence
- (3) Other causes.

Where possible, such immediate notification shall allow the Superintendent to initiate appropriate countermeasure action at the POTW. The user shall prepare a detailed written statement following any accidental or slug discharge, which describes the causes of the discharge and the measures being taken to prevent future occurrences, within five (5) days of the occurrence, and the Wastewater Treatment Plant Operator shall receive a copy of such report no later than the fifth calendar day following the occurrence. Analytical results and their interpretation may be appended to the report at a date not exceeding 45 calendar days after the occurrence.

When required by the Wastewater Treatment Plant Operator, detailed plans and procedures to prevent accidental or slug discharges shall be submitted to the Wastewater Treatment Plant Operator, for approval. These plans and procedures shall be called a Spill Prevention, Control, and Countermeasure (SPCC) Plan. The plan shall address, at a minimum, the following:

- (a) Description of discharge practices, including non-routine batch discharges;
- (b) Description of stored chemicals;
- (c) Procedures for immediately notifying the POTW of any accidental or slug discharge. Such notification must also be given for any discharge which would violate any provision of the permit and any National Prohibitive Discharge Standard;
- (d) Procedures to prevent adverse impact from any accidental or slug discharge. Such procedures include, but are not limited to, inspection and maintenance of storage areas, handling and transfer of materials, loading and unloading operations, control of plant site run-off, worker training, building of containment structures or equipment, measures for containing toxic organic pollutants (including solvents), and/or measures and equipment for emergency response.

Section 912 - Posting Notices

In order that the Industrial User's employees be informed of the Town of Hague

requirements, a notice shall be permanently posted on appropriate bulletin boards within the user's facility advising employees of the Town of Hague requirements and whom to call in case of an accidental discharge in violation of this Law.

Section 913 - Sample Splitting

When so requested in advance by an industrial user, and when taking a sample of industrial wastewater, the Town of Hague representative(s) shall gather sufficient volume of sample so that the sample can be split into two nearly equal volumes, each of size adequate for the anticipated analytical protocols including any Quality Control (QC) procedures. One of the portions shall be given to the representative of the industrial user whose wastewater was sampled, and the other portion shall be retained by the Town of Hague for its own analysis.

Section 914 - Public Access to Information Maintained by the Town

When requested, the Wastewater Treatment Plant Operator shall make available, to the public, for inspection and/or copying, information and data on industrial users obtained from reports, questionnaires, permit applications, permit and monitoring programs, and inspections, unless the Industrial User specifically requests, and is able to demonstrate to the satisfaction of the Wastewater Treatment Plant Operator, that such information, if made public, would divulge processes or methods of production entitled to protection as trade secrets of the user. Wastewater constituents and characteristics, and reports of accidental discharges shall not be recognized as confidential.

Confidential information shall not be made available for inspection and/or copying by the public but shall be disclosed, upon written request, to governmental agencies, for uses related to this Law, or the SPDES Permit, providing that the governmental agency making the request agrees to hold the information confidential, in accordance with State or Federal Laws, Rules and Regulations. The Wastewater Treatment Plant Operator shall provide written notice to the industrial user of any disclosure of confidential information to another governmental agency.

Section 915 A - Access to Property and Records

The Wastewater Treatment Plant Operator and other authorized representatives of the Town of Hague, representatives of EPA, NYSDEC, and NYSDOH, bearing proper credentials and identification, shall be permitted to enter upon all non-residential properties at all times for the purpose of inspection, observation, sampling, flow measurement, and testing to ascertain a user's compliance with applicable provisions of Federal and State law governing use of the Town of Hague POTW, and with the provisions of this Law. Inspections of residential properties shall be performed in proper observance of the resident's civil rights. Such representative(s) shall have the right to set up, on the User's property or property rented/leased by the User, such devices as are necessary to conduct sampling or flow measurement. Guard dogs shall be under proper control of the User while the representatives are on the User's property or property rented/leased by the User. Such representative(s) shall, additionally have access to and may copy any records the User is

required to maintain under this Law. Where a User has security measures in force which would require proper identification and clearance before entry into the premises, the user shall make necessary arrangements so that upon presentation of suitable identification, inspecting personnel will be permitted to enter, without delay, for the purpose of performing their specific responsibilities.

Section 915 B - Access to Easements

The Wastewater Treatment Plant Operator, bearing proper credentials and identification, shall be permitted to enter all private premises through which the Town of Hague holds an easement for the purpose of inspection, observation, measurement, sampling, repair, and maintenance of any portion of the Town of Hague public sewer system lying within the easement. All entry and subsequent work on the easement shall be done in accordance with the terms of the easement pertaining to the private premises involved.

Section 915 C - Liability of Property Owner

During the performance, on private premises, of inspections, sampling, or other similar operations referred to in Sections 1014 A and 1014 B, the inspectors shall observe all applicable safety rules established by the owner or occupant of the premises. The owner and/or occupant shall be held harmless for personal injury or death of the inspector and the loss of or damage to the inspector's supplies and/or equipment; and the inspector shall indemnify the owner and/or occupant against loss or damage to property of the owner or occupant by the inspector and against liability claims asserted against the owner or occupant for personal injury or death of the inspector or for loss of or damage to the inspector's supplies or equipment arising from inspection and sampling operations, except as such may be caused by negligence or failure of the owner or occupant to maintain safe conditions.

Section 916 - Special Agreements

Nothing in this Article shall be construed as preventing any special agreement or arrangement between the Town of Hague and any User of the POTW whereby wastewater of unusual strength or character is accepted into the POTW and specially treated, subject to any payments or user charges, as may be applicable. In entering into such a special agreement, the Town of Hague Board shall consider whether the wastewater will:

- (1) pass-through or cause interference
- (2) endanger the public municipal employees
- (3) cause violation of the SPDES Permit
- (4) interfere with any Purpose stated in Section 102
- (5) prevent the equitable compensation to the Town of Hague for wastewater conveyance and treatment, and sludge management and disposal

No discharge which violates the Federal Pretreatment Standards will be allowed under the terms of such special agreements.

No agreement shall be entered into without the user having been issued and presently having a permit to discharge wastes into the POTW for treatment and disposal. Additionally the user shall be in compliance with all conditions in the permit and shall not be in arrears in any charges due to the Town of Hague before the agreement is entered into. The Town of Hague Board may condition the agreement.

Article 10

Enforcement And Penalties

Section 1001 - Enforcement Response Plan

Administrative Remedies

Section 1002 - Notification of Violation Section 1103 - Consent Orders

Section 1004 - Administrative or Compliance Orders

Section 1005 - Administrative Fines

Section 1006 - Cease and Desist Orders

Section 1007 - Termination of Permit

Section 1008 - Show Cause Hearing

Section 1009 - Failure of User to Petition the Town

Section 1010 - Notice

Section 1011 - Right to Choose Multiple Remedies

Judicial Remedies

Section 1012 - Civil Actions for Penalties

Section 1013 - Court Orders

Section 1014 - Criminal Penalties

Section 1015 - Injunctive Relief

Section 1016 - Summary Abatement

Miscellaneous

Section 1017 - Delinquent Payments

Section 1018 - Performance Bonds

Section 1019 - Liability Insurance

Section 1020 - Public Notification

Section 1021 - Contractor Listings

Section 1001 - Enforcement Response Plan

The Wastewater Treatment Plant Operator shall prepare an Enforcement Response Plan. The Enforcement Response Plan, in a step-by-step fashion, shall outline the procedures to be followed to identify, document, and respond to violations by Users of the POTW. All violations by Users of the POTW shall be met with some type of enforcement response. The response shall be comprehensive and effective.

The Enforcement Response Plan shall:

- (1) describe how the Wastewater Treatment Plant Operator will investigate instances of non-compliance
- (2) describe the types of escalated enforcement actions that the Wastewater Treatment Plant Operator will take in response to all anticipated types of User violations and the time periods within which to initiate and follow-up these actions
- (3) adequately reflect the Town of Hague Board's responsibility to enforce all applicable standards and requirements.

The Enforcement Response Plan shall contain:

- (1) criteria for scheduling periodic inspection and/or sampling visits to POTW Users
- (2) forms and guidelines for documenting compliance data in a manner which will enable the information to be used as evidence
- (3) systems to track due dates, compliance schedule milestones, and pending enforcement actions
- (4) criteria, responsible personnel, and procedures to select and initiate an enforcement action.

The range of appropriate enforcement actions shall be based on the nature and severity of the violation and other relevant factors, such as:

- magnitude of the violation
- duration of the violation
- effect of the violation on the receiving water
- effect of the violation on the POTW
- effect of the violation on the health and safety of the POTW employees
- compliance history of the User
- good faith of the User
- and shall promote consistent and timely use of enforcement remedies.

The Town of Hague Board shall approve the Enforcement Response Plan. The Enforcement

Response Plan shall be reviewed at least every five years.

Administrative Remedies

Section 1002 - Notification of Violation

Whenever the Wastewater Treatment Plant Operator finds that any User has violated or is violating this Law, or any Wastewater Discharge Permit, order, prohibition, limitation, or requirement permitted by this Law, the Wastewater Treatment Plant Operator may serve upon such person a written notice stating the nature of the violation. Within ten (10) calendar days of the date the Zoning Enforcement Officer mails the notice, an explanation of the violation and a plan for the satisfactory correction and prevention thereof shall be submitted to the Wastewater Treatment Plant Operator, by the User. The correction and prevention plan shall include specific actions. Submission of this plan in no way relieves the User of liability for any violations caused by the User before or after receipt of the Notice of Violation.

Section 1003 - Consent Orders

The Wastewater Treatment Plant Operator is hereby empowered to enter into Consent Orders, assurances of voluntary compliance, or other similar documents establishing an agreement with the User responsible for the noncompliance. Such orders shall include specific action to be taken by the User to correct the noncompliance within a time period also specified by the order. Consent Orders shall have the same force and effect as an administrative order.

Section 1004 - Administrative or Compliance Orders

When the Wastewater Treatment Plant Operator finds that a User has violated or continues to violate this Law or a permit or administrative order issued there under, he may issue an administrative order to the User responsible for the discharge directing that, following a specified time period, sewer service shall be discontinued, severed and abated unless the violation is corrected and that there is no reoccurrence of the violation. Administrative orders may also contain such other requirements as might be reasonably necessary and appropriate to address the noncompliance, including the installation of pretreatment technology, additional self-monitoring, and management practices.

The User may, within fifteen (15) calendar days of receipt of such order, petition the Wastewater Treatment Plant Operator to modify or suspend the order. Such petition shall be in written form and shall be transmitted to the Wastewater Treatment Plant Operator by registered mail. The Wastewater Treatment Plant Operator shall then:

- (1) Reject any frivolous petitions,
- (2) Modify or suspend the order, or
- (3) Order the petitioner to show cause in accordance with Section 1109 and may as part of

the show cause notice request the User to supply additional information.

Section 1005 - Administrative Fines

Notwithstanding any other section of this Law, any User who is found to have violated any provision of this Law, or a wastewater discharge permit or administrative order issued hereunder, shall be fined in an amount not to exceed one thousand dollars (\$1,000.00) per violation. Each day on which noncompliance shall occur or continue shall be deemed a separate and distinct violation.

The User may, within fifteen (15) calendar days of notification of the Zoning Enforcement Officer's notice of such fine, petition the Town to modify or suspend the order. Such petition shall be in written form and shall be transmitted to the Wastewater Treatment Plant Operator by registered mail. The Wastewater Treatment Plant Operator shall then:

- (1) Reject any frivolous petitions,
- (2) Modify or suspend the fine, or
- (3) Order the petitioner to show cause in accordance with Section 1109 and may as part of the show cause notice request the User to supply additional information.

Section 1006 - Cease and Desist Orders

When the Wastewater Treatment Plant Operator finds that a User has violated or continues to violate this Law or any permit or administrative order issued hereunder, the Wastewater Treatment Plant Operator may issue an administrative order to cease and desist all such violations and direct those persons in noncompliance to:

- (1) Comply forthwith
- (2) Take such appropriate remedial or preventive action as may be needed to properly address a continuing or threatened violation, including halting operations or terminating the discharge.

The User may, within fifteen (15) calendar days of the date the Wastewater Treatment Plant Operator mails notification of such order, petition the Wastewater Treatment Plant Operator to modify or suspend the order. Such petition shall be in written form and shall be transmitted to the Wastewater Treatment Plant Operator by registered mail. The Wastewater Treatment Plant Operator shall then:

- (1) Reject any frivolous petitions,
- (2) Modify or suspend the order,
- (3) Order the petitioner to show cause in accordance with Section 1009 and may as part of

the show cause notice request the User to supply additional information.

Section 1007 - Termination of Permit

Any User who violates the following conditions of this Law or a wastewater discharge permit or administrative order, or any applicable or State and Federal law, is subject to permit termination: (1) Violation of permit conditions or conditions of an administrative order, (2) Failure to accurately report the wastewater constituents and characteristics of its discharge, (3) Failure to report significant changes in operations or wastewater constituents and characteristics, (4) Refusal of reasonable access to the User's premises for the purpose of inspection, monitoring, or sampling, or (5) Failure to pay administrative fines, fees or user charges. Non-compliant industrial Users will be notified, by registered mail, of the proposed termination of their wastewater permit. The User may, within fifteen (15) calendar days of the date the Wastewater Treatment Plant Operator mails such notification, petition the Wastewater Treatment Plant Operator to permit continued use of the POTW by the user. Such petition shall be in written form and shall be transmitted to the Zoning Enforcement Officer by registered mail. The Wastewater Treatment Plant Operator shall then: (1) Reject any frivolous petitions, (2) Order the petitioner to show cause in accordance with Section 1108 and may as part of the show cause notice request the User to supply additional information.

Section 1008 - Show Cause Hearing

The Wastewater Treatment Plant Operator may order any User appealing administrative remedies for violations of this Law to show cause, before the Town of Hague Board, why an enforcement action, initiated by the Wastewater Treatment Plant Operator, should not be taken. A notice shall be served on the User specifying the time and place of a hearing to be held by the Town of Hague Board regarding the violation, the reasons why the action is to be taken, the proposed enforcement action, and directing the User to show cause before the Town of Hague Board why the proposed enforcement action should not be taken. The notice of the hearing shall be served at least ten (10) calendar days before the hearing in accordance with Section 1010 of this Article. Service shall be made on any principal or executive officer of a User's establishment or to any partner in a User's establishment. The notice of the hearing shall be served at least ten (10) calendar days before the hearing, in accordance with Section 1010. The Town of Hague Board may itself conduct the hearing, or may designate any of its members or any officer or employee of the Town of Hague to conduct the hearing: (1) Issue, in the name of the Town of Hague Board, notices of hearings requesting the attendance and testimony of witnesses, and the production of evidence relevant to any matter involved in such hearings, (2) Take the evidence, (3) Take sworn testimony, (4) Transmit a report of the evidence and hearing, including transcripts and other evidence, together with recommendations to the Town of Hague Board for action thereon. After the Town of Hague Board has reviewed the evidence and testimony, it may order the user to comply with the Wastewater Treatment Plant operator's order or fine, modify the Wastewater Treatment Plant Operator's order or fine, or vacate the Wastewater Treatment Plant Operator's order or fine.

Section 1009 - Failure of User to Petition the Town

In the event the Zoning Enforcement Officer issues any administrative order, terminates the User's permit, or makes any fine as set forth in this article, and the User fails, within the designated period of time set forth, to petition the Zoning Enforcement Officer, as provided in appropriate sections of this article, the User shall be deemed in default and its rights to contest the administrative order or fine shall be deemed waived.

Section 1010 - Notice

The notices, orders, petitions, or other notification which the User or Zoning Enforcement Officer shall desire or be required to give pursuant to any sections of this Law shall be in writing and shall be served personally or sent by certified mail or registered mail, return receipt requested, postage prepaid, and the notice, order, petition, or other communication shall be deemed given upon its mailing as provided herein. Any notice, administrative order, or communication mailed to the User pursuant to the sections of this Law shall be mailed to the User where the User's effluent is discharged into transmission lines to the Town of Hague's POTW. Any notice, petition, or other communication mailed to the Wastewater Treatment Plant Operator shall be addressed and mailed to the Town Hall of the Town of Hague.

Section 1011 - Right to Choose Multiple Remedies

The Wastewater Treatment Plant Operator shall have the right, within the Wastewater Treatment Plant Operator's sole discretion, to utilize any one or more appropriate administrative remedies set forth in this Article. The Wastewater Treatment Plant Operator may utilize more than one administrative remedy established pursuant to this Article, and the Wastewater Treatment Plant Operator may hold one show cause hearing combining more than one enforcement action.

Judicial Remedies

Section 1012 - Civil Actions For Penalties

Any person who violates any of the provisions of or who fails to perform any duty imposed by this Law, or any administrative order or determination of the Zoning Enforcement Officer promulgated under this Law, or the terms of any permit issued hereunder, shall be liable to the Town of Hague for a civil penalty not to exceed one thousand dollars (\$1000) for each such violation, to be assessed after a hearing (unless the User waives the right to a hearing) held in conformance with the procedures set forth in this Article. Each violation shall be separate and distinct violation, and in the case of continuing violation, each day's continuance thereof shall be deemed a separate and distinct violation. Such penalty may be recovered in an action brought by the Town of Hague attorney, or his designated attorney, at the request of the Wastewater Treatment Plant Operator in the name of the Town of Hague, in any court of competent jurisdiction giving preference to courts local to the Town of Hague. In addition to the above described penalty, the Wastewater Treatment Plant Operator may recover all damages incurred by the Town of Hague from any persons or Users who

violate any provisions of this Law, or who fail to perform any duties imposed by this Law or any administrative order or determination of the Zoning Enforcement Officer promulgated under this Law, or the terms of any permit issued hereunder. In addition to the above described damages, the Wastewater Treatment Plant Operator may recover all reasonable attorney's fees incurred by the Town of Hague in enforcing the provisions of this Article, including reasonable attorney's fees incurred in any action to recover penalties and damages, and the Wastewater Treatment Plant Operator may also recover court costs, and other expenses associated with the enforcement activities, including sampling and monitoring expenses.

In determining the amount of civil penalty, the court shall take into account all relative circumstances, including, but not limited to the extent of harm caused by the violation, the magnitude and duration, any economic benefit gained through the User's violation, corrective actions by the User, the compliance history of the User, and any other relative factors as justice may require.

Such civil penalty may be released or compromised by the Wastewater Treatment Plant Operator before the matter has been referred to the Town of Hague attorney, and where such matter has been referred to the Town of Hague attorney, any such penalty may be released or compromised and any action commenced to recover the same may be settled and discontinued by the Town of Hague attorney, with the consent of the Wastewater Treatment Plant Operator.

Section 1013 - Court Orders

In addition to the power to assess penalties as set forth in this Article, the Wastewater Treatment Plant Operator shall have the power, following the hearing held in conformance with the procedures set forth in this Article, to seek an order:

- (1) Suspending, revoking, or modifying the violator's Wastewater Discharge Permit, or
- (2) Enjoining the violator from continuing the violation.

Any such court order shall be sought in an action brought by the Town of Hague attorney, at the request of the Zoning Enforcement Officer, in the name of the Town of Hague, in any court of competent jurisdiction giving precedence to courts local to the Town of Hague.

The Town of Hague attorney, at the request of the Wastewater Treatment Plant Operator shall petition the Court to impose, assess, and recover such sums imposed according to this Article. In determining amount of liability, the Court shall take into account all relevant circumstances, including, but not limited to, the extent of harm caused by the violation, the magnitude and duration, any economic benefit gained through the User's violation, corrective actions by the User, the compliance history of the User, and any other factor as justice requires.

Section 1014 - Criminal Penalties

Any person who willfully violates any provision of this Law or any final determination or administrative order of the Wastewater Treatment Plant Operator made in accordance with this Article shall be guilty of a Class A Misdemeanor, and upon conviction thereof, shall be punished by a fine of not less than Five Hundred Dollars (\$500) nor more than One Thousand Dollars (\$1,000), or imprisonment not to exceed one (1) year or both. Each offense shall be a separate and distinct offense, and, in the case of a continuing offense, each day's continuance thereof shall be deemed a separate and distinct offense.

Any User who knowingly makes any false statements, representations, or certifications in any application, record, report, plan or other document filed or required to be maintained pursuant to this Law, or wastewater permit, or who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required under this Law shall be guilty of a Class A Misdemeanor and, upon conviction, shall be punished by a fine of not more than One Thousand Dollars (\$1,000.00) per violation per day or imprisonment for not more than one (1) year or both.

No prosecution, under this Section, shall be instituted until after final disposition of a show cause hearing, if any, was instituted.

Section 1015 - Additional Injunctive Relief

Whenever a User has violated or continues to violate the provisions of this Law or permit or order issued hereunder, the Zoning Enforcement Officer, through counsel may petition the Court, in the name of the Town of Hague, for the issuance of a preliminary or permanent injunction or both (as may be appropriate) which restrains the violation of, or compels the compliance with any order or determination there under by the Wastewater Treatment Plant Operator.

Section 1016 - Summary Abatement

Notwithstanding any inconsistent provisions of this Law, whenever the Wastewater Treatment Plant Operator finds, after investigation, that any User is causing, engaging in, or maintaining a condition or activity which, in the judgment of the Wastewater Treatment Plant Operator, presents an imminent danger to the public health, safety, or welfare, or to the environment, or is likely to result in severe damage to the POTW or the environment, and it therefore appears to be prejudicial to the public interest to allow the condition or activity to go unabated until notice and an opportunity for a hearing can be provided, the Wastewater Treatment Plant Operator may, without prior hearing, order such User by notice, in writing wherever practicable or in such other form as practices are intended to be proscribed, to discontinue, abate, or alleviate such condition or activity, and thereupon such person shall immediately discontinue, abate, or alleviate such condition or activity; or where the giving of notice is impracticable, or in the event of a User's failure to comply voluntarily with an emergency order, the Wastewater Treatment Plant Operator may take all appropriate action to abate the violating condition. As promptly as possible thereafter, not to exceed fifteen (15) calendar days, the Wastewater Treatment Plant Operator shall provide the User an opportunity to be heard, in accordance with the provisions of this Article.

If the User is not within the geographic boundaries of the Town of Hague the right of summary abatement to discontinue, abate, or alleviate conditions or activities shall be those prescribed in the inter-municipal agreement.

The Wastewater Treatment Plant Operator, acting upon the belief that an emergency exists, shall be indemnified against any personal liability that may arise in the performance of his duties to protect the public health, safety, or welfare, or to preserve the POTW or the environment.

Miscellaneous

Section 1017 - Delinquent Payments

All unpaid sewer rent will be sent to Warren County Treasurer and added to the Town & County tax bill.

Section 1018 - Performance Bonds

The Wastewater Treatment Plant Operator may decline to reissue a permit to any User which has failed to comply with the provisions of this Law or any order or previous permit issued hereunder unless such User first files with it a satisfactory bond, payable to the POTW, in a sum not to exceed a value determined by the Wastewater Treatment Plant Operator to be necessary to achieve consistent compliance.

Section 1019 - Liability Insurance

The Wastewater Treatment Plant Operator may decline to reissue a permit to any User which has failed to comply with the provisions of this Law or any order or previous permit issued hereunder, unless the User first submits proof that it has obtained financial assurances sufficient to restore or repair POTW damage caused by its discharge.

Section 1020 - Public Notification

The Wastewater Treatment Plant Operator Shall provide public notification, in the daily newspaper with the largest circulation in the Town of Hague, of Users which were in significant non-compliance of local or Federal pretreatment standards or requirements since the last such notice. The frequency of such notices shall be at least once per year.

Section 1021 - Contractor Listings

(1) Users which have not achieved consistent compliance with applicable pretreatment standards and requirements are not eligible to receive a contractual award for the sale of goods or services to the Town of Hague.

(2) Existing contracts for the sale of goods or services to the Town of Hague held by a User found to be in significant violation with pretreatment standards may be terminated at the discretion of the Town of Hague Board.

Article 11

Charges

- Section 1101 - Normal Sewage Service Charges
- Section 1102 - Surcharge for Abnormal Sewage
- Section 1103 - Total Sewer Service Charge
- Section 1104 - Segmenting the POTW
- Section 1105 - Billing Period
- Section 1106 - Charges for Trucked and Hauled Wastes
- Section 1107 - Capital Recovery
- Section 1108 - Collection of Charges
- Section 1109 - Fiscal Year for System
- Section 1110 - Impact Fees
- Section 1111 - Use of Revenues
- Section 1112 - Records and Accounts

Section 1101 - Normal Sewage Service Charges

All persons discharging or depositing wastes into the public sewers shall pay a sewer service charge as per user unit schedule.

Section 1102 - Surcharge for Abnormal Sewage

All persons discharging or depositing wastes with concentrations in excess of the pollutant concentrations in normal sewage shall pay a surcharge.

Section 1103 - Total Sewer Service Charge

The total sewer service charge, (which shall be called the "User Charge"), is comprised of two parts, as follows:

$$UC(t) = UC(n) + UC(an)$$

Where:

UC(t) = total User Charge for POTW operation and maintenance

UC(n) = User Charge associated with normal sewage

UC(an) = User Charge associated with abnormal sewage

$$UC(n) = OM \times (OQ/100) \times (QIA/QA)$$

$$UC(an) = OM \{ [OB/100 \times (BIA-Bn)/BA] +$$

$$[OS/100 \times (SIA-Sn)/SA] +$$

$$[OP/100 \times (PIA-Pn)/PA] +$$

$$[ONH/100 \times (NHIA-NHn)/NHA] +$$

$$[OTK/100 \times (TKIA-TKn)/TKA] \}$$

Where:

OM = total annual POTW operation and maintenance costs
 OQ = percentage of OM attributable to flow (Q)
 OB = percentage of OM attributable to BOD5
 OS = percentage of OM attributable to suspended solids
 OP = percentage of OM attributable to total phosphorus
 ONH = percentage of OM attributable to ammonia
 OTK = percentage of OM attributable to total Kjeldahl nitrogen
 QIA = average daily flow rate (MGD) from discharger
 BIA = average daily BOD5 loading (LB/DAY) from discharger
 SIA = average daily suspended solids loading (LB/DAY) from discharger
 PIA = average daily total phosphorus loading (LB/DAY) from discharger
 NHIA = average daily ammonia loading (LB N/DAY) from discharger TKIA = average daily total Kjeldahl nitrogen loading (LB N/DAY) from discharger
 QA = average daily flow rate (MGD) at the POTW treatment plant
 BA = average daily BOD5 loading (LB/DAY) at the POTW treatment plant
 SA = average daily suspended solids loading (LB/DAY) at the POTW treatment plant
 PA = average daily total phosphorus loading (LB/DAY) at the POTW treatment plant
 NHA = average daily total ammonia loading (LB N/DAY) at the POTW treatment plant
 TKA = average daily total Kjeldahl nitrogen loading (LB N/DAY) at the POTW treatment plant
 Bn = BOD5 loading (LB/DAY) in discharge if it were normal sewage
 Sn = suspended solids loading (LB/DAY) in discharge if it were normal sewage
 Pn = total phosphorus loading (LB/DAY) in discharge if it were normal sewage
 NHn = ammonia loading (LB N/DAY) in discharge if it were normal sewage
 TKn = total Kjeldahl nitrogen loading (LB N/DAY) in discharge if it were normal sewage
 Note: if any difference terms in the equation above is negative, then that portion of the equation shall not be used, that is, the difference shall be set to zero when it is negative.

Note: all averages are arithmetic averages determined from available data during the billing period.

Section 1104 - Segmenting the POTW

The service area of the POTW may be segmented to assist in a fair distribution of user charges, especially if there is a pump station serving a segment.

Section 1105 - Billing Period

The Billing Period shall be yearly.

Section 1106 - Charges for Trucked and Hauled Wastes

The charge for treatment and disposal of trucked or hauled waste which has been introduced into the POTW shall be as established by the Town of Hague Board. The manner of determining the volume dumped shall be at the discretion of the Wastewater Treatment Plant Operator.

Section 1107 - Capital Recovery

The Town of Hague may institute an equitable procedure for recovering the costs of any capital improvements of those parts of the POTW which collect, pump, treat, and dispose of industrial wastewaters from those persons discharging such wastewaters into the POTW.

Section 1108 - Collection of Charges

Provisions of Article 11 of this Law relating to the collection of penalties shall apply to the collection of Sewer Service Charges and Abnormal Sewage Service Surcharges, unless where otherwise provided by application of the Sewer Rent Law by Town of Hague.

Section 1109 - Fiscal Year for System

The POTW shall be operated on the basis of a fiscal year commencing on the first day of January and ending on the thirty-first day of December.

Section 1110 - Impact Fees

The Town of Hague (Board) shall have the authority to impose impact fees on new development, which development may:

- (1) - cause enlargement of the service area of the POTW
- (2) - cause increased hydraulic and/or treatment demands on the POTW

Section 1111 - Use of Revenues

Revenues derived from user charges and associated penalties, and impact fees, shall be credited to a special fund. Monies in this fund shall be used exclusively for the following functions:

- (a) For the payment of the operation and maintenance, including repair and replacement costs of the Town of Hague POTW,
- (b) For the discovery and correction of inflow and infiltration,
- (c) For the payment of interest on and the amortization of or payment of indebtedness which has been or shall be incurred for the construction or extension of the Town of Hague POTW,
- d) For the extension, enlargement, replacement of, and/or additions to the Town of Hague POTW, including any necessary appurtenances.

Section 1112 - Records and Accounts

The Town of Hague shall maintain and keep proper books of records and accounts for the POTW, separate from all other records and accounts, in which shall be made full and correct entries of all transactions relating to the POTW. The Town of Hague will cause an annual

audit of such books of record and account for the preceding fiscal year to be made by a recognized independent certified public accountant, and will supply such audit report to authorized officials, and the public, on request.

In conjunction with the audit, there shall be an annual review of the sewer charge system to determine if it is adequate to meet expenditures for all programs for the coming year.

Classification of old and new industrial users should also be reviewed annually.

The Town of Hague shall maintain and carry insurance on all physical properties of the POTW, of the kinds and in the amounts normally carried by public utility companies and municipalities engaged in the operation of sewage disposal systems. All moneys received for losses under any such insurance policies shall be applied solely to the replacement and restoration of the property damaged or destroyed.

Article 12

Public Disclosure Of POTW Operations

Section 1201- POTW Operations Open to the Public

Section 1202- Procedural Requirements Available

> Section 1203- Validity Through Public Inspection

Section 1201- POTW Operations Open to the Public

It shall be the policy of the Town of Hague (Board) to conduct all business with full disclosure to the public.

Section 1202- Procedural Requirements Available

The nature and requirements of all formal procedures for applying for a permit and for requesting a permit under this Law and for requesting a hearing shall be formulated by the Town of Hague and be made available to any resident of the Town of Hague upon request.

Section 1203- Validity Through Public Inspection

The Town of Hague shall formulate procedures to make available to the public for inspection such orders, statements of policy, and interpretations used by the Town of Hague in administration of this Law. No rule, regulation, or civil order shall be valid until it has been available for public inspection.

Article 13

Conflicts, Severability, Effective Date And Applicability

Section 1301- Conflicts

Section 1302- Severability

Section 1303- Effective Date

Section 1304- Applicability

Section 1301- Conflicts

The provisions of any Town of Hague law in conflict with any provision of this Law are hereby repealed.

Section 1302- Severability

Each provision of this Law is severable from the others, so that if any provision is held to be illegal or invalid for any reason whatsoever, such illegal or invalid provision shall be severed from this Law which shall nonetheless remain in full force and effect.

Section 1303- Effective Date

This law shall take effect 30 days after it's filing in the office of the Secretary of State.

Section 1304- Applicability

Articles 1, 2, 4, 8, 11, 12, 13 and 14 shall apply in all incorporated areas of the Town of Hague. Articles 3, 5, 6, 7, 9 and 10 shall apply only in incorporated areas of the Town of Hague which are also within the service area of the POTW.

Appendix

Parameters of Concern

Class A - Halogenated Hydrocarbons

Class B - Halogenated Organics (Other than Hydrocarbons)

Class C - Pesticides (Includes Herbicides, Algaecides, Biocides, Slimicides and Mildewcides)

Class D - Aromatic Hydrocarbons

Class E - Tars

Class F - Substituted Aromatics (Other than Hydrocarbons and Non-Halogenated)

Class G - Miscellaneous

Class M - Metals and their Compounds

Class A - Halogenated Hydrocarbons

A01. Methyl Chloride

A02. Methylene Chloride

A03. Chloroform

A04. Carbon Tetrachloride

A05. Freon/Genatron

A06. Other Halomethanes

A07. 1,1,1-Trichloroethane

A08. Other Haloethanes

A09. Vinyl Fluoride

A10. Vinyl Chloride

A11. Dichloroethylene

A12. Trichloroethylene

A13. Tetrachloroethylene

A14. Chlorinated Propane

- A15. Chlorinated Propene
- A16. Hexachlorobutadiene
- A17. Hexachlorocyclopentadiene
- A18. Chlorinated Benzene
- A19. Chlorinated Toluene
- A20. Fluorinated Toluene
- A21. Polychlorinated Biphenyl (PCB)
- A22. Chlorinated Naphthalene
- A23. Dechlorane (C₁₀Cl₁₂)
- A24. Hexachlorocyclohexane (BHC)

A99. Halogenated Hydrocarbons Not Specified Above

Class B - Halogenated Organics (Other than Hydrocarbons)

- B01. Phosgene
- B02. Methyl Chloromethyl Ether
- B03. Bis-Chloromethyl Ether
- B04. Other Chloroalkyl Ethers
- B05. Benzoyl Chloride
- B06. Chlorothymol
- B07. Chlorinated Phenol
- B08. Chlorinated Cresols or Xylenols
- B09. Chlorendic Acid
- B10. Chloroaryl Ethers
- B11. Dichlorophene or Hexachlorophene
- B12. Chlorinated Aniline (Including Methylene Bis)(2-Chloroaniline)
- B13. Dichlorobenzidine
- B14. Chlorinated Diphenyl Oxide
- B15. Chlorinated Toluidine
- B16. Kepone (C₁₀Cl₁₀O)
- B17. Dichlorovinyl Sulfonyl Pyridine
- B18. Chloropicrin
- B19. Trichloromethyl Thio-Phthalimide
- B20. Trichloro-Propylsulfonyl Pyridine
- B21. Tetrachloro-Methylsulfonyl Pyridine
- B22. Tetrachloro-Isophthalonitrile

B99. Halogenated Organics Not Specified Above

Class C - Pesticides (Includes Herbicides, Algacides, Biocides, Slimecides and Mildewcides)

- C01. Aldrin/Dieldrin
- C02. Chlordane and Metabolites
- C03. DDT and Metabolites
- C04. Endosulfan/Thiodan and Metabolites
- C05. Endrin and Metabolites

- C06. Heptachlor and Metabolites
- C07. Malathion
- C08. Methoxychlor
- C09. Parathion
- C10. Toxaphene
- C11. Sevin
- C12. Kelthane
- C13. Diazinon
- C14. Dithane
- C15. Carbaryl
- C16. Silvex
- C17. Dithiocarbamates
- C18. Maneb
- C19. Dioxathion
- C20. Tandex/Karbutilate
- C21. Carbofurans
- C22. Pentac
- C23. Folpet
- C24. Dichlone
- C25. Rotenone
- C26. Lindane/Isotox
- C27. Simazine
- C28. Methoprene

C99. Pesticides Not Specified Above
Class D - Aromatic Hydrocarbons

- D01. Benzene
- D02. Toluene
- D03. Xylene
- D04. Biphenyl
- D05. Naphthalene
- D06. Ethylbenzene
- D07. Styrene
- D08. Acenaphthene
- D09. Fluoranthene

D99. Aromatic Hydrocarbons Not Specified Above
Class E - Tars

- E01. Coal Tar
- E02. Petroleum Tar

E99. Tars Not Specified Above
Class F - Substituted Aromatics (Other than Hydrocarbons and Non-Halogenated)

- F01. Phenol, Cresol or Xylenol
- F02. Catechol, Resorcinol, or Hydroquinone
- F03. Nitrophenols
- F04. Nitrobenzenes
- F05. Nitrotoluenes
- F06. Aniline
- F07. Toluidines
- F08. Nitroanilines
- F09. Nitroanisole
- F10. Toluene Diisocyanate
- F11. Dimethylaminoazobenzene
- F12. Benzoic Acid (and Benzoate Salts)
- F13. Phthalic, Isophthalic or Terephthalic Acid
- F14. Phthalic Anhydride
- F15. Phthalate Esters
- F16. Phenoxyacetic Acid
- F17. Phenylphenols
- F18. Nitrobiphenyls
- F19. Aminobiphenyls (Including Benzidine)
- F20. Diphenylhydrazine
- F21. Naphthylamines
- F22. Carbazole
- F23. Acetylamino fluorene
- F24. Dyes and Organic Pigments
- F25. Pyridine

F99. Substituted Aromatics Not Specified Above

Class G - Miscellaneous

- G01. Asbestos
- G02. Acrolein
- G03. Acrylonitrile
- G04. Isophorone
- G05. Nitrosamines
- G06. Ethyleneimine
- G07. Propiolactone
- G08. Nitrosodimethylamine
- G09. Dimethylhydrazine
- G10. Maleic Anhydride
- G11. Methyl Isocyanate
- G12. Epoxides
- G13. Nitrofurans
- G14. Cyanide

Class M - Metals and Their Compounds

- M01. Antimony

M02. Arsenic
M03. Beryllium
M04. Cadmium
M05. Chromium
M06. Copper
M07. Lead
M08. Mercury
M09. Nickel
M10. Selenium
M11. Silver
M12. Thallium
M13. Zinc

M99. Metals Not Specified Above